

STUDY COMPLETION

STUDY COMPLETION

NOTICE OF STUDY COMPLETION

SUSTAINABLE HALTON WATER AND WASTEWATER MASTER PLAN CLASS ENVIRONMENTAL ASSESSMENT STUDY NOTICE OF COMPLETION

BACKGROUND

The Sustainable Halton Water and Wastewater Master Plan provides a Region-wide review, evaluation and development of water and wastewater servicing strategies for all urban service areas. The Master Plan has used updated planning population and employment estimates for the 2031 planning horizon based on the Best Planning Estimates as endorsed by Halton Regional Council. As shown in the map, the urban areas under study includes the South Halton systems in Burlington, Oakville, Milton, Halton Hills 401 Corridor; as well as the North Halton systems in Georgetown and Acton. This Master Plan builds on the previous work undertaken as part of the South Halton Master Plans and Updates, related studies for the North Halton systems and the Wastewater Pumping Station Capital Needs Assessment and Master Plan Study for Oakville and Burlington. This Master Plan is a critical component in the integrated planning process of the Sustainable Halton program and provides the framework and vision for the water and wastewater servicing needs within the urban areas in Halton Region to 2031.

PROBLEM STATEMENT

To identify preferred water and wastewater servicing strategies to meet the existing needs of Halton Region as well as Halton's growth needs to the year 2031.

PROCESS

This study has been undertaken in accordance with the requirements for master plans under Section 4, Approach #2 of the Municipal Class Environmental Assessment (EA) document (October 2000 as amended in 2007) which is approved under the Ontario Environmental Assessment Act, and will satisfy Phase 1 and 2 of the planning process.

Under the Sustainable Halton Water and Wastewater Master Plan process, servicing strategies were developed, then evaluated against natural, social and technical criteria, and then ultimately selected as the preferred solution to meet the system requirements and growth needs of Halton Region to year 2031.

Public Information Centres (PICs) were held in each local municipality to provide master plan information as well as obtain feedback. The first round of PIC's were held in May and June 2010 to introduce the study to the general public, outline the problem/opportunity statement and to provide background information, guiding policies, vision and servicing concepts. The preliminary preferred water and wastewater Master Plan servicing strategies were presented at a second round of PICs held in each local municipality in February and March 2011.

Following input received from PICs, review agencies and other key stakeholders consultation, the Class EA Study Report for the Water and Wastewater Master Plan recommends the preferred water and wastewater servicing strategies and identifies a list of projects.

Subject to comments received as a result of this notice, Halton Region intends to proceed with the implementation of the recommended Schedule A, A+ and B projects included in the Class EA Master Plan Study Report.


PUBLIC COMMENT INVITED

By this notice, the Class EA Study Report for the Sustainable Halton Master Plan which documents the planning process undertaken and conclusions reached will be on public record for 30 calendar days in accordance with the Municipal Class EA Document. The Public "Review Period" will begin on Thursday, October 13, 2011 and end on Monday, November 14, 2011

The Class EA Study Report for the Sustainable Halton Master Plan is available for public review at the following locations:

City of Burlington , 426 Brant Street, Clerk's Department M-F 8:45am – 4:30pm	Town of Halton Hills , 1 Halton Hills Drive, Georgetown, Clerk's Department M-F 8:30am – 4:30pm
Town of Milton , 150 Mary Street, Clerk's Department M-F 8:30am – 4:30pm	Town of Oakville , 1225 Trafalgar Road, Clerk's Department M-F 8:30am – 4:30pm
Region of Halton , 1151 Bronte Road, Citizen's Reference Library M-F 8:30am – 4:30pm	

The documents are also available electronically at: www.halton.ca/EAs.



If, after reading the Class EA Master Plan, you have any questions or concerns, please follow the subsequent procedure:

1. Contact any of the following individuals to discuss your questions or concerns:

David Simpson, P.Eng. Manager of Water Planning Halton Region Phone: 905-825-6000 Ext. 7601 Fax: 905-825-8822 E-mail: david.simpson@halton.ca	John Duong, P.Eng. Manager of Wastewater Planning Halton Region Phone: 905-825-6000 Ext. 7961 Fax: 905-825-8822 E-mail: john.duong@halton.ca	Chris Hamel, P.Eng. Project Manager AECOM Phone: 905-747-7562 Fax: 905-886-9494 E-mail: chris.hamel@aecom.com
---	--	---

2. Arrange a meeting with the above if you have significant concerns that may require more detailed explanation.

3. If major concerns are raised, the Region will attempt to negotiate a resolution of the issues. A mutually acceptable time period for this negotiation will be set. If the issues remain unresolved, you have the option to request the Minister of the Environment, by order, to require the Region to comply with Part II of the Environmental Assessment Act before proceeding with a Schedule B project. This is called a Part II Order ("bump up"). Part II Orders cannot be submitted in respect of the Master Plan itself, but must be made in respect to individual Schedule B projects listed in this Notice. The Minister may make one of the following decisions:

- Deny the request
- Refer the matter to mediation
- Require the Region to comply with Part II of the Environmental Assessment Act by undertaking one of the following:
 - Submitting the Class EA Master Plan for government review and approval
 - Completing an Individual Environmental Assessment for government review and approval
 - Preparing Terms of Reference governing the preparation of an individual Environmental Assessment.

Requests for a Part II Order must be submitted, in writing, to the Minister of the Environment within the **October 13, 2011 to November 14, 2011** review period:

Minister of Environment

Environmental Assessment and Approvals Branch
135 St. Clair Avenue West, 12th Floor
Toronto, ON M4V 1P5

A copy of the Part II Order must also be sent to Halton Region, to the attention of the Project Managers (address above).

Information will be collected in accordance with the **Freedom of Information and Protection of Privacy Act**. With the exception of personal information, all comments will become part of the public record.

This notice issued October 13 / 14 and October 20 / 21, 2011.

SUSTAINABLE HALTON WATER AND WASTEWATER MASTER PLAN UPDATE CLASS ENVIRONMENTAL ASSESSMENT STUDY NOTICE OF COMPLETION - continued

This Notice of Completion is issued with respect to the recommended Schedule A, A+, and B Master Plan Projects. The list of Schedule A and A+ Master Plan projects can be accessed electronically at the study web page previously noted. The Schedule B and C Master Plan projects and their respective identification numbers are noted below. To receive a copy of the list of Schedule A, A+, B and C projects, please contact any of the project managers or review the Class EA Study Report at the location previously noted.

SCHEDULE B - ACTIVITIES SUBJECT TO THE SCREENING PROCESS

Burlington	
6367	120 ML/d Burloak Water Pumping Station Construction, Phase 1, 50 MLD (Zone B2)
6601	7.8 ML/d Expansion at Beaufort Water Pumping Station (new site) (Zone B5)
6665	400 mm WM between Tyandaga Reservoir and Beaufort Reservoir (Zone B4)
6670	2.5 ML Water storage Expansion at Beaufort Reservoir (new site) (Zone B4)
6701	Kitchen Zone O3 Water Pumping Station Expansion by 80 ML/d
6863	Waterdown Road Water Pumping Station Expansion (Zones B2, B3A & B5A)
Halton Hills	
6572	1050 mm WWM on Steeles Ave from 8th Line to Crossing Easement
5061	30 ML Water Reservoir, near Trafalgar Road and No.5 Sideroad (Zone M4)
6570	24 MLD WWPS at 10 Side Rd/9th Line (275 L/s)
6589	3 ML/d WWPS on 10th Side Rd in Norval (35 L/s)
6606	750 mm WM on Trafalgar from the new Zone 4 Reservoir to approximately 1,650 m north (Zone G6L)
6607	750 mm WM on Trafalgar Rd from 1,650 m north of Zone 4 Reservoir to No 10 Sideroad (Zone G6L)
6608	750 mm WM on Trafalgar from 15th Sideroad to 22nd Sideroad Lake Based Reservoir (Zone G6L)
6614	600 mm WM on Adamson St from 10th Sideroad to Guelph St and on Guelph St from Adamson St to 10th Sideroad (Zone G6L)
6693	20 ML/d Water pumping station at Zone 4 Reservoir (Zone G6L)
6694	10 ML Water Storage Reservoir at 22nd Sideroad (Zone G6L)
6696	20 ML/d Water pumping station at Zone M4L Reservoir (Zone M5L)
Milton	
6555	17 ML/d WWPS on Tremaine Rd (200 L/s)
6571	104 ML/d WWPS on Trafalgar Rd/ Britannia Rd (1200 L/s)
6573	1050 mm WWM 401 Crossing from Steeles Ave to Auburn Rd
6574	1050 mm WWM on Auburn Rd from Hwy 401 crossing easement to Trafalgar Rd
6584	156 ML/d WWPS at Lower Base Line and 4th Line (1805 L/s)
6640	600 mm WM on Trafalgar Rd from Zone 4 Reservoir to 600 mm Zone M5L WM on Steeles Avenue (ID 3844) (Zone M5L)
6688	400 mm WM on Trafalgar Rd from Steeles Avenue to Hwy 401 (Zone M5L)
6689	400 mm WM on Trafalgar Rd Hwy 401 Crossing (Zone M5L)
6690	400 mm WM on Trafalgar Rd from Hwy 401 to Main St Extension (Zone M5L)
Oakville	
6661	900 mm WM Second Feedermain to Davis Road Booster Pumping Station (Zone O1)
6663	400 mm WM from 9th Line on easement to Bristol Circle (Zone O3)
6541	Deep Trunk Sewer on Rebecca St and Lakeshore Rd W from Wilson St to Oakville SW WWTP
Region	
6686	Bulk Water Stations on New Sites

SCHEDULE C - ACTIVITIES SUBJECT TO ADDITIONAL STUDY THROUGH PHASES 3 & 4 OF THE MUNICIPAL CLASS EA PROCESS AND ARE NOT SUBJECT TO THIS NOTICE OF COMPLETION

Notification will be issued when these projects proceed to Phases 3 & 4 of the Municipal Class EA Process

Halton Hills	
5717	Prospect Park WPP Expansion from 2.3 to 3.5 ML/d (Zone A9G)
6437	Acton Well Field Development and Treatment (Zone A9G)
6598	300 mm WM from New Well to Reg Rd 25 (Zone A9G)
6677	Acton Water Artificial Recharge Capital Works
6679	Georgetown Water Artificial Recharge Capital Works
6695	Centralized Water Treatment Plant at 3rd line Reservoir (Zone A9G)
Milton	
6585	Twinned 900 mm WWFM from Lower Base Line to RR 25
Oakville	
6588	Mid-Halton WWTP Expansion from 125 ML/d to 175 ML/d
6681	Oakville WPP Intake Pipe Extension
6684	Oakville WPP Expansion from 109 to 130 ML/d
6700	Burloak WPP Expansion from 165 ML/d to 220 ML/d

**WM=Watermain WPP=Water Purification Plant WWM=Wastewatermain
WWFM=Wastewater Forcemain WWPS=Wastewater Pumping Station
WWTP=Wastewater Treatment Plant MLD=mega litres per day
ML=mega litres mm-millimetres m=meters**

STUDY COMPLETION

RESPONSE LETTERS



Public Works
Water and Wastewater Services
1151 Bronte Road
Oakville ON L6M 3L1

October 7, 2011

Dear Resident/Business Owner,

**RE: SUSTAINABLE HALTON WATER AND WASTEWATER MASTER PLAN
MUNICIPAL CLASS ENVIRONMENTAL ASSESSMENT STUDY**

Halton Region has completed the Water and Wastewater Master Plan. This final Report recommends a preferred long term servicing strategy for all municipal water and wastewater systems within the urban boundary of Halton, integrating existing and future servicing needs to the year 2031.

As a potential stakeholder in the study, we are writing to inform you that the preferred servicing strategy has recommended new water or wastewater infrastructure adjacent to or on a portion of your property. As such, we would like to discuss specific infrastructure property requirements with you in more detail. The proposed water and wastewater projects are noted in the Master Plan Report which is available for your review at any of the five locations identified in the enclosed Notice of Completion or electronically at:

www.halton.ca/planning_sustainability/environmental_assessments__eas_/

Should you have any comments or additional questions regarding the study, please feel free to contact David Simpson at 905-825-6000 ext. 7601 (via email at david.simpson@halton.ca) or John Duong at 905-825-6000 ext. 7961 (via email at john.duong@halton.ca). You can also contact Chris Hamel at 905-747-7562 (via email at chris.hamel@aecom.com).

Sincerely,

Halton Region

David Simpson, P.Eng.
Manager of Water Planning

Halton Region

John Duong, P.Eng.
Manager of Wastewater Planning

AECOM Canada Ltd.

Chris Hamel, P.Eng.
Project Manager

encl. Notice of Completion

The Regional Municipality of Halton

STUDY COMPLETION

COMMENTS / RESPONSE MATRIX

First & Last Name	Title	Company	Address	City, Prov	Postal Code	Type	Comment	Date	Status/Response
Resident						Reply Form	- Interested in providing comments, would like to remain on contact list	April 19, 2010	- Added to mailing list June 16, 2010 - Sent Notice of Completion, October 13/14, 2011
Resident						Comment Sheet	- Suggestion that option 3A should consider a Georgetown only feed along Boivert (Hwy 7) fed by new storage tanks on Mississauga Rd. - Enquiry about Halton and Peel agreements	April 19, 2010	- Added to mailing list July 20, 2010 - Sent response letter acknowledging comments, with invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
Resident						Comment Sheet	- Expressed disappointment at the PIC boards statements on the subject of Lindsay Court Well - The same standpoint on the wells was taken by the Region/Gartner-Lee two years ago	April 20, 2010	- Already on contact list - Sent invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
Walter H. Watt	Property Administrator	Trans Northern Pipelines Inc.	45 Vogel Rd, Suite 310	Richmond Hill, ON	L4B 3P6	Reply Form	- TNPI is interested in the extent of proposed water mains or sewer lines will interact with existing TNPI facilities in southern Oakville and Burlington - Crossings would be subject to National Energy Board Act and pipeline crossing regulations	May 12, 2010	- Already on mailing list - Sent response letter acknowledging comments, with invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
Nathan Stewart	Transportation Technologist	Halton Region Cycling Committee	1151 Bronte Road	Oakville, ON	L6M 3L1	Reply Form	- Please remove from mailing list	May 13, 2010	- Removed from mailing list June 20, 2010
Diana Beaulne	Right of Way Approval Technician	Enbridge Gas Distribution Planning	500 Consumers Rd, 4th Floor	North York ON	M2J 1P8	Email	- Keep updated with project - During engineering design send copies of plans per normal procedure	May 14, 2010	- Already on mailing list - Sent response letter acknowledging comments, with invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
Dan Steele	Director of Engineering	Oakville Hydro	P.O. Box 1900, 861 Redwood Square	Oakville, ON	L6J 5E9	Reply Form	- Agency is interested in providing input into the study	May 14, 2010	- Already on mailing list - Sent invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
Cathy Roberston	Director of Roads & Parks Maintenance,		PO Box S013	Burlington, ON	L7R 3Z6	Reply Form	- Please advise if there are any technical agencies meetings or if the PICs are meant to be the contact points for local municipal stakeholders	May 17, 2010	- Already on mailing list - Sent response letter acknowledging comments, with invitation to PIC #2
Jackie Van De Valk	Rural Planner	Ontario Ministry of Agriculture, Rural Affairs	6484 Wellington Rd, Unit 10	Elora West, ON	NOB 1S0	Reply Form	- Agency is interested in providing input into the study	May 17, 2010	- Added to mailing list July 20, 2010 - Sent invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
John Boich		Rambo Creek Ratepayers Association	2085 Caroline St.	Burlington, ON	L7R 1L6	Reply Form	- Agency is not interested in providing input regarding the study	May 20, 2010	- Removed from mailing list June 20, 2010
Jeff Booker	Manager, Highway Engineering	407 ETR	6300 Steeles Avenue West	Woodbridge, ON	L4H 1J1	Reply Form	- Agency is interested in providing input into the study	May 20, 2010	- Added to mailing list July 20, 2010 - Sent response letter acknowledging comments, with invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
Don Boswell	Senior Claims Analyst	Indian & Northern Affairs	10 Wellington Street	Gatineau, QC	K1A 0H4	Reply Form	- No facilities in Halton Region - Agency is not interested in providing input regarding the study - Remove from contact list	May 20, 2010	- Removed from contact list June 1, 2010
Renee Brown	Council and Committee Services Coordinator (TEAC)	Town of Halton Hills	1 Halton Hills Drive	Halton Hills, ON	L7G 5G2	Reply Form	- Agency is interested in providing input into the study	May 20, 2010	- Added to mailing list July 20, 2010 - Sent invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
Anita Fabac	Sr. Policy Analyst	Region of Halton, Long Range Planning	1151 Bronte Road	Oakville, ON	L6M 3L1	Reply Form	- Agency is interested in providing input into the study	May 20, 2010	- Added to mailing list July 20, 2010 - Sent invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
John Hall	HHRAP Co-ordinator	Canada Centre for Inland Waters	P.O. Box 5050	Burlington, ON	L7R 4A6	Reply Form	- Interested in the Skyway WWTP	May 20, 2010	- Already on mailing list - Sent response letter acknowledging comments, with invitation to PIC #2
Business Owner						Letter	- Enquiring in to personal incorporation into the municipal water system due to belief that existing well system is contaminated - Received confirmation from Region of Halton that property will be within the new Milton 2031 boundary	May 20, 2010	- Added to mailing list July 16, 2010 - Sent response letter acknowledging comments, with invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
Stephanie Jarvis	Environmental Planner	Town of Milton	150 Mary Street	Milton, ON	L9T 6Z5	Reply Form	- Agency is interested in providing input into the study	May 20, 2010	- Already on mailing list - Sent response letter acknowledging comments, with invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
Christine Lacombe	TEAC Chair Person	Town of Halton Hills	29 Grey Owl Run	Georgetown, ON	L7G 5Z8	Reply Form	- Agency is interested in providing input into the study - Add Renee Brown to the mailing list	May 20, 2010	- Renee Brown added to mailing list - Sent invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
Julie Anne Lamberts	Water Resources Technician and Project Coordinator	Credit Valley Conservation	1255 Old Derry Rd	Mississauga, ON	L5N 6R4	Reply Form	- Agency is interested in providing input into the study	May 20, 2010	- Already on mailing list - Sent response letter acknowledging comments, with invitation to PIC #2

First & Last Name	Title	Company	Address	City, Prov	Postal Code	Type	Comment	Date	Status/Response
Jennifer Lawrence	Manager, Environmental Planning	Conservation Halton	2596 Britannia Rd West	Milton, ON	L9T 2X7	Reply Form	- Agency is interested in providing input into the study - Particular areas of interest include; source protection, water quality and quantity, river/shoreline impacts, fish habitat impacts	May 20, 2010	- Already on mailing list - Sent invitation to PIC #2 - Pre-filing consultation - Sent Notice of Completion, October 13/14, 2011
Liam Marray	Sr. Planner/Ecologist	Credit Valley Conservation	1255 Old Derry Rd	Mississauga, ON	L5N 6R4	Reply Form	- Agency is interested in providing input into the study - Acton and Georgetown – potential impacts to watercourses and other natural features, assimilative capacity etc.	May 20, 2010	- Already on mailing list - Sent invitation to PIC #2 - Pre-filing consultation - Sent Notice of Completion
Ann Newman	Damage Prevention Team Lead	Enbridge Pipelines Inc.	801 Upper Canada Dr	Sarnia, ON	N7W1A3	Reply Form	- Agency is not interested in providing input regarding the study but would like to be kept informed - Enbridge Pipelines Inc. Owns and operated high pressure petroleum Pipelines within the study area and new infrastructure may impact the pipelines/ROW	May 20, 2010	- Already on mailing list - Sent invitation to PIC #2
Shelley Partridge/Margaret Smith	Sr. Planner, Development Project Manager	Region of Halton	1151 Bronte Rd.	Oakville, ON	L6M 3L1	Reply Form	- Agency is interested in providing input into the study	May 20, 2010	- Added to mailing list July 20, 2010 - Sent invitation to PIC #2
Dave Pitablo		Paletta International Corporation	4480 Paletta Court	Burlington, ON	L7L 5R2	Reply Form	- Agency is interested in providing input into the study	May 20, 2010	- Added to mailing list July 20, 2010 - Sent response letter acknowledging comments, with invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
Myron Pestaluky	President	Delta Urban Inc.	7501 Keele St, Suite 505	Vaughan, ON	L4K 1Y2	Reply Form	- Agency is interested in providing input into the study	May 20, 2010	- Added to mailing list - Sent invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
Chris Povell		Sr. Consultant Inc.	2290 Queensway Drive	Burlington, ON	l7R 3T2	Reply Form	- Agency is interested in providing input into the study	May 20, 2010	- Already on mailing list - Sent invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
Domenico Renzella	Manager of Planning	Halton District School Board	PO Box 5005 STN LCD 1	Burlington, ON	L7R 3Z2	Reply Form	- Agency is not interested in providing input regarding the study but would like to be kept informed	May 20, 2010	- Already on mailing list - Sent invitation to PIC #2
Morley Richardson	President	208222 Ontario Ltd & 368785 Ontario Ltd.	346 Bishop Crt	Milton, ON	L9T 3N1	Reply Form	- Agency is interested in providing input into the study - Interested in information regarding the South East Corner Regional Road #25S & Derry Rd, Milton	May 20, 2010	- Already on mailing list - Sent response letter acknowledging comments, with invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
Lori Ritter	Lands Resource Worker	Hiawatha First Nation	123 Paudash Street RR#2	Keene, ON	K0L 260	Reply Form	- interested in any archaeological finds or environmental concerns	May 20, 2010	- Added to mailing list July 20, 2010 - Sent invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
Ric Robertshaw	Director of Wastewater	Region of Peel	10 Peel Centre Drive	Brampton, ON	L6T 4B9	Reply Form	- Agency is interested in providing input into the study - Interested in Water and Wastewater	May 20, 2010	- Already on mailing list - Sent response letter acknowledging comments, with invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
Jason Sheldon	V.P Land Development	The Remington Group Inc	7501 Keele Street, Suite 100	Vaughan, ON	L4K 1Y2	Email & Reply Form	- Agency is interested in providing input into the study	May 20, 2010	- Already on mailing list - Sent invitation to PIC #2
Paul Smeltzer	Principal Consultant	AMEC Earth & Environmental	3215 North Service Road	Burlington, ON	L7N 3G2	Reply Form	- Agency is interested in providing input into the study	May 20, 2010	- Added to mailing list July 20, 2010 - Sent invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
Carlo Stefanutti	Vicw President	Fieldgate Developments	5400 Yonge Street, 5th Floor	Toronto, ON	MZN 5T5	Reply Form	- Interested in all aspects of the Master Plan	May 20, 2010	- Already on mailing list - Sent response letter acknowledging comments, with invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
Paul Sytsma	Senior Partner	Urban Tech Consulting	25 Royal Crest Court, Ste 201	Markham, ON	L3R 9X4	Reply Form	- Agency is interested in providing input into the study - Water and Lands that drain into Grindstone Crescent	May 20, 2010	- Already on mailing list - Sent invitation to PIC #2 - Sent specific response letter and Notice of Completion, October 13/14, 2011
Tys Theysmeyer	Head of Conservation	Royal Botanical Gardens	680 Plains Road West	Burlington, ON	L7T 4H4	Reply Form	- Agency is interested in providing input into the study - Water and Lands that drain into Grindstone Crescent	May 20, 2010	- Already on mailing list - Sent response letter acknowledging comments, with invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
Jim Vanderkooy	Principal	King's Christian Collegiate	528 Burnhamthorpe Road West	Oakville, ON	L6M 4K6	Reply Form	- Interested in when wastewater infrastructure will be provided to their site	May 20, 2010	- Already on mailing list - Sent response letter acknowledging comments, with invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
Tim Warner	Vice President	Mattamy Development Corporation	2360 Bristol Circle	Oakville, ON	L6H 6M5	Reply Form	- No comments	May 20, 2010	- Already on mailing list - Sent response letter acknowledging comments, with invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011

First & Last Name	Title	Company	Address	City, Prov	Postal Code	Type	Comment	Date	Status/Response
Lisa Myslicki	Environmental Coordinator		1 Dundas Street West, Suite 2000	Toronto, ON	M5G 2L5	Letter	- Potential negative impacts to Ontario Realty Corporation - Heritage Management process and Environmental Assessment (EA) Process - Potential triggers related to MEI's Class EA	May 21, 2010	- Already on mailing list - Sent response letter acknowledging comments, with invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
Greg Sage	EMS Chief	Halton Region EMS	1179 Bronte Rd	Oakville, ON	L6M 4G3	Reply Form	- Agency is not interested in providing input regarding the study but would like to be kept informed.	May 21, 2010	- Already on mailing list - Sent response letter acknowledging comments, with invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
Sarah Horwath, On behalf of Scott Bland	Assessment & Planning Clerk	Halton Catholic District School Board	802 Drury Lane	Burlington, ON	L7R 2Y2	Email & Reply Form	- No comments	May 25, 2010	- Added to mailing list - Sent invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
Resident						Comment Sheet	- Highlighted the need for good public relations/awareness	May 26, 2010	- Added to mailing list July 16, 2010 - Sent response letter acknowledging comments, with invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
Resident						Reply Form	- Interested in alternatives to the 'big pipe' solution for Halton Hills - Requested a hard copy	May 26, 2010	- Already on mailing list - Hard copy sent as requested - Region sent personalized response letter dated Oct. 22, 2010 - Sent response letter acknowledging comments, with invitation to PIC #2
Daniel Delaquis	Environmental Resource Planner & EA Coordinator	(Air, Pesticides and Environmental Planning)	5775 Yonge Street, 9th Floor	Toronto, ON	M2M 4J1	Letter	- Submittal of concerns, where the main concerns Expressed were: Ecosystem Protection and restoration, surface water, groundwater, air quality, servicing and facilities, contaminated soils, mitigation and monitoring, planning and policy, Class EA process, First Nations Consultation	May 27, 2010	- Already on mailing list - Sent response letter acknowledging comments, with invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
Josse Beauregard	Litigation Team Leader	Indian & Northern Affairs	25 Eddy Street	Gatineau, QC	K1A 0H4	Letter	- Ligation Letter	May 30, 2010	- Added to mailing list - Sent response letter acknowledging comments, with invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
Rob Witham	Senior Project Engineer	MMM Group	100 Commerce Valley Drive West	Markham, ON	L3T 7P8	Reply Form	- Tracking/reviewing on behalf of client – Metro Ontario	May 31, 2010	- Already on mailing list - Sent response letter acknowledging comments, with invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
Chief Sharon Stinson Henry	Chief	Council, Rama First Nation	5884, Rama Road, Suite 200	Rama, ON	L0K 1T0	Letter	- PIC information was forwarded to Karry Sandy-McKenzie, Barrister & Solicitor Coordinator for Williams Treaties First Nations	June 2, 2010	- Already on mailing list - Sent response letter acknowledging comments, with invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
Douglas McGill	President	McGill Development Services Ltd.	311 Byron Street North	Whitby, ON	L1N 4N4	Email	- Request for PIC presentation	June 2, 2010	- Formal response given stating PIC board availability online - Sent invitation to PIC #2 - Sent specific response letter and Notice of Completion, October 13/14, 2011
Ron Baldessarra		Randvest Inc.	5285 Solar Drive	Mississauga, ON	L4W 5B8	Comment sheet & Email	- Land owner stating concerns about the potential application of expensive servicing alternatives in external areas i.e. outside north Oakville	June 3, 2010	- Already on mailing list - Sent response letter acknowledging comments, with invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
Ruth Thoen		Redbourne Realty Advisors inc.	5500 North Service Road, Suite 306	Burlington, ON	L7L 6W6	Email	-Change of company name and address	June 3, 2010	- Address change July 19, 2010 - Sent invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
John Taglieri		Lormel Homes	30 Pennsylvania Ave. Unit 16	Concord, ON	L4K 4A5	Email	- Request for PIC presentation	June 4, 2010	- Formal response given stating PIC board availability online - Sent invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
James Etienne	Senior Water Resources Eng.	Grand River Conservation Authority	400 Clyde Road	Cambridge, ON	N1R 5W6	Letter & Reply Form	- Stated continued interest in participation of this study - Particular interest shown in the water budget issues at the boundary of Grand, Credit and Halton Watersheds - Ruling out of concept 5 where there is an interconnection with Wellington County. It is felt that if there is an intra basin transfer is required from the Grand River water shed to the Credit River Watershed would result in 'short circuiting' the flow to Lake Ontario - Inflow/infiltration (I/I) reductions have been outlined as a solution to reduce the Acton wastewater treatment capacity. If the infiltration portions of I/I have been identified as a significant quantity affecting the source of the Prospect Well, then I/I reductions should be considered as a condition of expanding the well's PTTW to ensure the ongoing sustainability of the water source.	June 4, 2010	- Added to mailing list July 20, 2010 - Sent response letter acknowledging comments, with invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011

First & Last Name	Title	Company	Address	City, Prov	Postal Code	Type	Comment	Date	Status/Response
Resident						Letter	- Awaiting a copy of investigative study regarding an aquifer to be located south of 15 th Side Road between Trafalgar and the Eighth Line	June 7, 2010	- Added to contact list June 20, 2010 - Copy of PIC report sent out - Region sent out personalized response letter dated Jun 29, 2010 - Sent invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
Clark Somerville	Councillor					Email	- Requesting a copy of the full PIC presentation	June 7, 2010	- Region of Halton replied with a link to the presentation via the study website - Sent invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
Diane Bloomfield	Project Manager	Halton-Hamilton Source Protection Region	4052 Milborough Line, RR#2	Campbellville, ON	L0P 1B0	Reply Form	- Comments to be provided through Conservation Halton	June 8, 2010	- Already on mailing list - Sent response letter acknowledging comments, with invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
Resident						Email	- Enquiry about feedback deadline dates	June 8, 2010	- Halton sent a reply welcoming PIC feedback within the June 16th cut off - Sent invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
Douglas McGill	President	McGill Development Services Ltd.	311 Byron Street North	Whitby, ON	L1N 4N4	Reply Form	- Recommends that the Region of Halton maximizes use and future water and wastewater infrastructure alignment, sizing, and timing of delivery to ensure efficient and cost effective delivery of water and wastewater infrastructure	June 16, 2010	- Already on mailing list (previous comment sent Jun 2, 2010) - Sent response letter acknowledging comments, with invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
Paul Brown	C.E.T. Director, Land Development	MTE Consultants Inc.	3115 Harvester Road, Suite 200	Burlington, ON	L7N 3N8	Email	- Response on behalf of client: Orianna Glen Home Corp. Orianna owns land located south of Orianna Road between Fourth Line and Fifth Line in the Town of Milton - States that lands have been incorporated as Residential and Mixed Use Area within the Sustainable Preferred Land Use Plan (ROPA 38) which is currently awaiting Provincial Consent. Lands located immediately North, Boyne Survey Secondary Plan – Town of Milton Official Plan Amendment No.30 was approved by Town Council on June 14th, 2010 - As noted the lands are incorporated in the Preferred Land Use Plan and are immediately coincident to the existing boundary, MTE believes that the subject lands should be part of the next Secondary Plan Area in the Town of Milton	June 17, 2010	- Already on mailing list-Sent response letter acknowledging comments, with invitation to PIC #2 - Sent specific response letter and Notice of Completion, October 13/14, 2011
Resident						Email	- Concerned about the water quality of Fairy Lake and its effect on residents health	June 28, 2010	- Halton sent reply with a link to Water Quality Reports - Sent invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
Gordon Patterson	Principal Delta Urban Inc.	The Sernas Group on behalf of	Southwest Georgetown Landowners Group (SWGLOG)			Letter	- Written on behalf of SWGLOG who own 1000 hectares of land in the Regions identified expansion area bounded by Trafalgar Road, 15 th Sideroad, Main Street/8 th Line and 10 th Sideroad -General Comments: Sernas highlight financial and phasing impacts as the most important factors. Highlighted a need for a 'critical mass' of development to support the infrastructure and a potential need for temporary works. - Request that Best Planning Estimates (BPE) will be released as soon as possible - Stated support for W5A 'Connect to the Lake based system in South Halton - Shows encouragement for the development of both groundwater and lake based initiatives concurrently. - Georgetown WW Servicing Alternatives: Supportive of the WW3B "Trunk Sewer Diversion – Send flows to the South Halton WW System". However Sernas do show concern regarding the South Lake Wastewater concepts, pointing in particular towards the gravity flow concepts running southward from Georgetown from the 401 down Trafalgar through the Milton East expansion area. Given the large amount of development land available in Milton this may have the knock on effect of again delaying development in Georgetown again. - Timing: Request that the service options for Georgetown as soon as possible	June 29, 2010	- Added to mailing list July 20, 2010 - Sent response letter acknowledging comments, with invitation to PIC #2 - Sent specific response letter and Notice of Completion, October 13/14, 2011
Resident						Email	-Question regarding the extent of water withdrawn from the Lake Ontario and its natural replenishment	November 4, 2010	- Halton sent reply with links for further details - Sent invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
David Scott		The Municipal Infrastructure Group	8800 Dufferin Street, Suite 200	Vaughan, ON	L4K 0C5	Email	- Following up to get brief update on the Master Plan status and next steps	January 18, 2011	- Region responded with the key actions and status of the Master Plan deliverables on Jan. 18, 2011 - Sent specific response letter and Notice of Completion, October 13/14, 2011
Walter H. Watt	Property Administrator	Trans-Northern Pipelines Inc.	45 Vogell Road, Suite 310	Richmond Hill, ON	L4B 3P6	Email (Attached Letter)	- Confirms that Trans-Northern's pipelines cross study area from west to east within the City of Burlington and the Town of Oakville, south of QEW - Facilities must adhere to Pipeline Crossing Regulations and guidelines - Attached Pipeline Neighbours Organization information and pipeline facilities map	February 7, 2011	- Added to mailing list - Sent Notice of Completion, October 13/14, 2011
Patricia Coca	Distribution Engineer	Halton Hills Hydro Engineering Dept.		Acton, ON	L7J 2A9	Email	- Updating load forecast to ensure sufficient supply capacity and circuitry to where development is planned - Request for information regarding Halton Hills preliminary preferred alternatives - Add to mailing list	February 8, 2011	- Region of Halton replied on February 8, 2011 by forwarding preliminary presentation slides - Added to mailing list - Sent Notice of Completion, October 13/14, 2011

First & Last Name	Title	Company	Address	City, Prov	Postal Code	Type	Comment	Date	Status/Response
Junior Francis	Utilities Coordinator	CN Railway	4 Welding Way	Concord, ON	L4K 1B9	Email	- Keep CN informed of any work that may fall in right-of-way - Add to mailing list	February 8, 2011	- Added to mailing list, February 8, 2011 - Sent Notice of Completion, October 13/14, 2011
Cynthia Robinson	Environment and Education Manager	Ontario Stone, Sand and Gravel Association	5720 Timberlea Blvd, Unit 103	Mississauga, ON	L4W 4W2	Email	- Add to mailing list - Remove Jane White from mailing list	February 8, 2011	- Added to mailing list - Jane White removed from mailing list.
Michael Barton	Vice President	Landmart Homes	337 Parkridge Crescent	Oakville, ON	L6M 1A8	Email	- Keep informed throughout all phases of project - Add to mailing list	February 9, 2011	- Added to mailing list, March 16, 2011 - Sent response letter, March 16, 2011 - Sent Notice of Completion, October 13/14, 2011
Lisa Myslicki	Environmental Coordinator	Ontario Realty Corporation	1 Dundas Street West, Suite 2000	Toronto, ON	M5G 2L5	Email (Attached Letter and map)	- Ontario Realty Corporation managed property is within the study area (attached small map) - Outlined potential negative impacts to the environment ORC tenants, land holdings, and cultural heritage features - Potential triggers related to the Ministry of Energy and Infrastructure's Class EA have been identified - Requested copy of draft EA report and review time (30 days) for comments prior to finalizing report, since project affects part of ORC managed property	February 11, 2011	- Added to mailing list - Sent Notice of Completion, October 13/14, 2011
Chief Sharon Stinson Henry		Council, Rama First Nation	5884, Rama Road, Suite 200	Rama, ON	L0K 1T0	Letter	- Acknowledges receipt of letter received February 7, 2011. - Copy of letter has been forwarded to Karry Sandy-McKenzie, Barrister & Solicitor, Coordinator for Williams Treaties First Nations for further review - Direct all future correspondence and inquires to, Ms. Sandy-McKenzie	February 14, 2011	- Already on mailing list - Sent response letter acknowledging comments, with invitation to PIC #2 - Sent Notice of Completion, October 13/14, 2011
Dave Simpson	Communications Officer, Lands and Resources	Alderville First Nations	11696 Second Line, P.O. Box 46	Roseneath, ON	K0K 2X0	Email (Attached Letter)	- Keep informed throughout all phases of project - Add to mailing list	February 16, 2011	- Added to mailing list February 17, 2011 - Sent Notice of Completion, October 13/14, 2011
Ron Young		KRPAN Group	2500 Appleby Line , Suite 200	Burlington, ON	L7L 02A	Email & Comment Sheet	- Add to mailing list - Request for comment sheet - No comments submitted - Request to be added to mailing list	February 18, 2011	- Added to mailing list February 23, 2011 - Sent specific response letter and Notice of Completion, October 13/14, 2011
Gerald Asa		The Effort Trust Company	242 Main Street East	Hamilton, ON	L8N 1H5	Email	- Owns the Market Place Plaza in Acton - Request for an executive summary pertaining to Acton	February 23, 2011	- Added to mailing list - Region of Halton replied with a website link to the presentation via the study website - Sent Notice of Completion, October 13/14, 2011
Matthew Ballaban		Gamsby and Mannerow Limited	650 Woodlawn Road West, Block C, Unit 2	Guelph, ON	N1K 1B8	Email	- Suggests considering making provisions to rechlorination facility at the proposed Zone 5 pumping station - If this is considered, chlorine boost would not be required at the Oakville WPP to accommodate potentially low chlorine considerations in the lake feed section of Georgetown	February 24, 2011.	- Added to mailing list, March 16, 2011 - Sent response letter, March 16, 2011 - Sent specific response letter and Notice of Completion, October 13/14, 2011
Resident						Questionnaire	- Believes that key flaw in study is that area must grow as mandated by the province, hence all options are flawed in this context - Believes development community wants pipe to Georgetown to give them unlimited lake water to allow for more development - Opposes the use of lake water in Georgetown	February 24, 2011	- Added to mailing list - Sent specific response letter and Notice of Completion, October 13/14, 2011
Resident						Comment Sheet	- Water conservation efforts should be employed to protect water resources - Conservation opportunities need to be identified - Suggests Region researches and promotes conservation Best Practices from other countries (Australia, California, etc.)	February 24, 2011	- Added to mailing list - Sent specific response letter and Notice of Completion, October 13/14, 2011
Resident						Comment Sheet	- Add to mailing list - No comments submitted	February 24, 2011	- Added to mailing list - Sent Notice of Completion, October 13/14, 2011
Colin Best	Regional Councillor	Milton Council	150 Mary Street	Milton, ON	L9T 6Z5	Email	- Expressing the views of Milton residents in wanting to keep escarpment well based water - Share concerns about the deterioration of Walker's Line Well and the reduced capacity at the Kelso wells to serve the existing Milton urban area - Phasing out of Walker's Line well is logical - Requests switching the commercial triangle of Main St. E and Nipising Rd both sides from Thompson Rd to Ontario St. including the Milton Mall - Where possible, employment and industrial areas west side of Bronte St. from Derry Rd to Steeles Ave including Robertson-Whitehouse plant at 97 Bronte St. north and industrial areas along the north side of Steeles Ave - After all other options have been exhausted, residential areas on a neighbourhood at a time basis will be switched after all residents have been informed of the proposal - With the recommended commercial, industrial, employment and institutional switchovers to the lake based system, proposed residential switchovers are not expected for a while	February 25, 2011.	- Already on mailing list - Sent response letter, March 16, 2011 - Sent Notice of Completion, October 13/14, 2011

First & Last Name	Title	Company	Address	City, Prov	Postal Code	Type	Comment	Date	Status/Response
Jim Steeves		Milton Green, Citizens Group	288 Bousfield Crescent	Milton, ON	L9T 3G7	Email	<ul style="list-style-type: none"> - Appreciated the open conversations with staff and consultants at the PIC - Mentions that nothing had been posted in local papers about the PIC, and felt caught 'off guard' when informed - Requests additional information that will interest citizens about the project to post in the Milton Green blog - Intends to present a balanced forum for discussion for everyone and would like any other feedback, comments, and recommendations that may be of interest to the public - Those on well water feel it is better as it doesn't contain contaminants which could be coming from industries upstream from the Lake Ontario intakes - Current science indicates no difference between the two water sources, but long-term impacts are unknown - Would like clarification about MOE Permit To Take Water limitations and the possibility of more water available related to the Kelso Well upgrades - Requests clarification whether industries NW South of the 401 take as much water as the town - Email correspondence between Jim and Halton Region, has been forwarded to Carol Gustafson from Milton Green as requested via telephone discussion 	February 25, 2011 March 2, 2011 March 4, 2011	<ul style="list-style-type: none"> - Already on mailing list - Region of Halton replied to emails on March 2, 2011 - Region of Halton replied to email on March 4, 2011 - Sent specific response letter and Notice of Completion, October 13/14, 2011
Lisa Tallyn	Staff Writer	GT Independent Free Press	280 Guelph Street, Unit 29	Georgetown ON	L7G 4B1	Email	<ul style="list-style-type: none"> - Requests information for an article to be published in the GT Independent Free Press Newspaper Questions: <ul style="list-style-type: none"> - Cedervale and Lindsay Court well capacity increase - Lake based pipe installation timing, cost, route - Timing of complete switch to lake based servicing for Georgetown South and Stewarttown - Capacity of new pipe, and sizing for future development - Next step in the Master Plan process 	February 28, 2011.	<ul style="list-style-type: none"> - Added to mailing list, March 16, 2011 - Region of Halton replied to email on February 28, 2011 - Sent response letter, March 16, 2011 - Sent Notice of Completion, October 13/14, 2011
Ron Baldessara	Represents Randvest Inc.		5285 Solar Drive	Mississauga, ON	L4W 5B8	Comment Sheet with attached map	<ul style="list-style-type: none"> - Randvest Inc. land is located north of the 407, SW corner of Trafalgar Road and Lower Base Line - Servicing alternatives do not accommodate these lands, that will be developed in the future - Attached sketch showing possible services of Randvest Inc. lands and other lands north of the 407 using future services to be entailed in the North Oakville Secondary Plan 	March 1, 2011	<ul style="list-style-type: none"> - Already on mailing list - Sent Notice of Completion, October 13/14, 2011
Christina Commisso	Journalist	Milton Canadian Champion	555 Industrial Drive	Milton, ON	L9T 5E1	Email	<ul style="list-style-type: none"> - Submitted exerts from the 'Ground to Lake Water' article for clarification, comments, changes 	March 2, 2011.	<ul style="list-style-type: none"> - Added to mailing list, March 9, 2011 - Sent response letter, March 16, 2011 - Sent Notice of Completion, October 13/14, 2011
Karry Sandy-McKenzie	Barrister & Solicitor, Coordinator for Williams Treaties First Nations Primary Contact for: Chief Sharon Stinson Henry		8 Creswick Court	Barrie, ON	L4M 2J7	Letter	<ul style="list-style-type: none"> - Acknowledges receipt of letter received February 7, 2011 - Copy of letter has been forwarded to Karry Sandy-McKenzie, Barrister & Solicitor, Coordinator for Williams Treaties First Nations for further review - Direct all future correspondence and inquires to Ms. Sandy-McKenzie 	March 1, 2011	<ul style="list-style-type: none"> - Both already on mailing list - Noted Karry Sandy-McKenzie as the primary contact for future correspondence and inquiries - Sent Notice of Completion, October 13/14, 2011
Resident						Email	<ul style="list-style-type: none"> - Suggests the expansion of wells to keep groundwater source servicing - Feels privileged to have had ground water source - Opposes the switch to lake based water as homes would need water-purification filters to eliminate unpleasant taste, bottled water, and continuous water treatment needed for an inevitable increase in lake pollution over time 	March 3, 2011.	<ul style="list-style-type: none"> - Added to mailing list, March 16, 2011 - Sent response letter, March 16, 2011 - Sent specific response letter and Notice of Completion, October 13/14, 2011
Richard Laughton	President	LMC CENSOL Group		Milton, ON	L9T 4N8	Email	<ul style="list-style-type: none"> - Add to mailing list - Requests documentation of proposed changes to the use of Kelso or Walker's Line Wells for old Milton 	March 3, 2011	<ul style="list-style-type: none"> - Region of Halton replied with a website link to the Master Plan Study - Added to mailing list, March 7, 2011 - Sent specific response letter and Notice of Completion, October 13/14, 2011
Resident						Email	<ul style="list-style-type: none"> - Opposes switch to lake bases system - Upset over proposed switch to lake base water for the Timberlea area to account for intensification in Milton downtown core - Concerned about impacts of redirecting sewage from the Timberlea neighbourhood to the Mid-Halton plant - Opposed to fluoride in water supply due to health risks - What are the potential impacts of the re-direction of sewage? - Why has the Timberlea area been chosen to be connected to the 'big pipe' as opposed to the proposed growth area? - Is it necessary to transition Timberlea to lake based in 5 years, when development approvals for intensification within the core will be time consuming and difficult to obtain? - Will conservation efforts eliminate the need for a lake based system for Timberlea? 	March 3, 2011.	<ul style="list-style-type: none"> - Added to mailing list, March 9, 2011 - Colin Best (Councillor Milton) replied to email on March 10, 2011. - Sent response letter, March 16, 2011 - Sent specific response letter and Notice of Completion, October 13/14, 2011
Resident						Email	<ul style="list-style-type: none"> - In favour of lake water for Timberlea - Had to deal with water softener for almost 30 years with the current system 	March 3, 2011	<ul style="list-style-type: none"> - Added to mailing list, March 7, 2011 - Sent specific response letter and Notice of Completion, October 13/14, 2011
Resident						Email	<ul style="list-style-type: none"> - Residents are pleased that fluoride isn't added to their water supply - Explains potential health risks when getting lake based water (i.e.. Dental fluorosis, lower thyroid) 	March 4, 2011.	<ul style="list-style-type: none"> - Added to contact list, March 9, 2011 - Sent response letter, March 16, 2011 - Sent specific response letter and Notice of Completion, October 13/14, 2011
Resident							<ul style="list-style-type: none"> - Provided comments in response to the article printed on March 3rd's Canadian Champion 	March 5, 2011	<ul style="list-style-type: none"> - Added to contact list - Sent specific response letter and Notice of Completion, October 13/14, 2011

First & Last Name	Title	Company	Address	City, Prov	Postal Code	Type	Comment	Date	Status/Response
Resident						Email	- Opposed to changing water source from Kelso wells to Lake Ontario system - Keep informed throughout all phases of project	March 6, 2011.	- Added to mailing list, March 9, 2011 - Sent response letter, March 16, 2011 - Sent specific response letter and Notice of Completion, October 13/14, 2011
Resident						Email	- Moved to Milton for the water source, enjoys Niagara escarpment aquifer water supply and disappointed to no longer have access to it - Initially assured that the existing residents would retain the escarpment sourced water when the 'Big Pipe' alternative was approved - Requests that other alternatives are considered	March 6, 2011.	- Added to mailing list, March 16, 2011 - Sent response letter, March 16, 2011 - Sent specific response letter and Notice of Completion, October 13/14, 2011
Resident						Email Comment Sheet	- Informed that Master Plan information has already been loaded on to the Halton website, but is unable to find the webpage for the Halton Master Plan and PIC 2 - Requests website link to information - Would have liked ad to state 'drop-in' format of PIC - Acronym definitions should have been available for lay persons - Directions to where to find presentation on the web should have been readily available - What is the breakdown figures behind Halton Regions 5% reduction in water use planned?	March 6, 2011. March 9, 2011.	- Region of Halton replied with a website link to the study website - Added to mailing list, March 9, 2011 - Sent response letter, March 16, 2011 - Sent Notice of Completion, October 13/14, 2011
Resident						Email	- Lives in Milton because of the water quality, without the use of chemicals and chlorine for treatment - Feels that switching to lake water would be detrimental to Dorset and Timberlea as well as other areas, would take away from the small town feel that Milton once had - Escarpment water tastes different than lake water - Opposed to switch to lake water due to the polluted state of lake water and the chemicals added during the treatment process	March 7, 2011.	- Added to mailing list, March 16, 2011 - Sent response letter, March 16, 2011 - Sent specific response letter and Notice of Completion, October 13/14, 2011
Resident						Email	- Concerned about lake water quality due to pollution, chemicals, etc. - Opposes the switch to lake based servicing	March 7, 2011.	- Added to mailing list, March 16, 2011 - Sent response letter, March 16, 2011 - Sent specific response letter and Notice of Completion, October 13/14, 2011
Resident						Email	- Change is inevitable in Milton due to its location in the provincial growth planning - Suggests seeking costing alternatives to switching over the industrial and commercial areas first - Switching over long-term industrial residents would help to alleviate any residential switchover for the near future, - That would be the preferred option to switching over drinking water from long established Milton residents	March 7, 2011.	- Added to mailing list, March 16, 2011 - Sent response letter, March 16, 2011 - Sent Notice of Completion, October 13/14, 2011
Resident						Email	- Disappointed to read in the Canadian Champion (Thursday March 3, 2011) that older parts of Milton would be switched to a lake based system - Moved to Milton for the small town experience and was ensured by the Town that further development would occur around their property - Initially promised by the Town etc. that the big pipe' water would stay on the perimeter of old areas, and would just service new houses - Disappointed to hear that the initial promise has been broken - Ultimately, opposed to the use of lake water for old Milton, including the Timberlea area	March 7, 2011.	- Added to contact list, March 9, 2011 - Sent response letter, March 16, 2011 - Sent specific response letter and Notice of Completion, October 13/14, 2011
Resident						Email	- Opposed to switching to lake water for Timberlea area - Proud to live in 'Old Milton' and would like things to remain the same - Unfair to give up ground water based on where in Milton people choose to live	March 8, 2011.	- Added to mailing list, March 16, 2011 - Sent response letter, March 16, 2011 - Sent specific response letter and Notice of Completion, October 13/14, 2011
David Schaeffer		David Schaeffer Engineering Ltd.	600 Alden Road, Suite 500	Markham, ON	L3R 0E7	Email	- Requested profile drawings for the sanitary sewers - Would like the opportunity to submit comments following engineers' technical meeting	March 8, 2011	- Added to mailing list, March 16, 2011 - Sent response letter, March 16, 2011 - Sent specific response letter and Notice of Completion, October 13/14, 2011
Resident						Comment Sheet	- Should shutdown Milton's in town sewage treatment plant	March 9, 2011.	- Added to mailing list, March 9, 2011 - Sent response letter, March 16, 2011 - Sent specific response letter and Notice of Completion, October 13/14, 2011
Resident						Comment Sheet	- Owners of the property listed post 2021-2031 - Requests that the property be developed now so it may be serviced - Very concerned that servicing is shown post 2021	March 9, 2011.	- Added to mailing list, March 9, 2011 - Sent response letter, March 16, 2011 - Sent specific response letter and Notice of Completion, October 13/14, 2011
Resident						Comment Sheet & Questionnaire	- Would like to keep the existing well water system - Supports preservation efforts being made for escarpment lands East of Bronte and North of Main St. - Suggests wastewater flows from Milton STP to be redirected due to overflows in the summer - Pleased by staffs efforts to single out questions and inquires from Residents - At what point are the proposed employment lands considered to be too far and too much?	March 9, 2011.	- Added to mailing list, March 9, 2011 - Sent response letter, March 16, 2011 - Sent specific response letter and Notice of Completion, October 13/14, 2011
David Leighton	Senior Partner	Urbantech Consulting	25 Royal Crest Court, Ste 201	Markham, ON	L3R 9X4	Letter	- On behalf of Milton Phase 3 Landowners Group (within Milton's Boyne Survey Secondary Plan Area) - Request more detail on the cost estimates prepared for the water and wastewater servicing strategies - Requested further discussion on the location of the wastewater pumping station, allowable sewer depths and forcemain locations - Requested further discussion regarding maximizing the capacity of existing water and wastewater infrastructure - Appreciated invitation to technical meeting on March 31, 2011	March 9, 2011	- Sent specific response letter and Notice of Completion, October 13/14, 2011

First & Last Name	Title	Company	Address	City, Prov	Postal Code	Type	Comment	Date	Status/Response
Resident						Email	- Opposed to Timberlea area changing to lake based water - According to the 2010 Annual Water Quality Report, the area only lists chlorine and potassium permanganate for the treatment process, while other lake based water areas require 9 other chemicals for the purification process (i.e.. Burlington, Burloak, Oakville and South Halton)	March 10, 2011.	- Added to mailing list, March 16, 2011 - Sent response letter, March 16, 2011 - Sent specific response letter and Notice of Completion, October 13/14, 2011
Paul Smeltzer	Principal Consultant	AMEC Earth & Environmental	3215 North Service Road	Burlington, ON	L7N 3G2	Email	- Requested any new information regarding the Boyne and Derry Green communities (already checked website)	March 10, 2011	- Sent specific response letter and Notice of Completion, October 13/14, 2011
David Scott	Founding Partner	The Municipal Infrastructure Group	8800 Dufferin Street, Suite 200	Vaughan, ON	L4K 0C5	Letter	- On behalf of Fieldgate Developments, who own lands within the Boyne Survey Community, north of Britannia Road and east of 16 Mile Creek - Concerned with location of the Britannia Rd WWPS, as shown in Preliminary Preferred Strategy as it will result in unnecessary depth of local sewers - Support the location of the Britannia Rd WWPS as shown just east of 16 Mile Creek in the South Halton Water and Wastewater Master Plan Update - Would like to work with Region and AECOM to refine the preferred strategy for the SH lands	March 10, 2011	- Sent specific response letter and Notice of Completion, October 13/14, 2011
David Scott	Founding Partner	The Municipal Infrastructure Group	8800 Dufferin Street, Suite 200	Vaughan, ON	L4K 0C5	Letter	- On behalf of Britannia South Landowners Group - TMIG carried out analysis and determined that the Britannia North/South lands can be serviced by the Britannia Rd trunk sewer and WWPS without the need for further deepening to service the Britannia South lands - Believe that design of Britannia Rd SPS can accommodate flows from the entire SH lands, including Britannia South lands (thereby eliminating need for a WWPS at Lower Base Line and crossing of 16 Mile Creek, and making use of existing infrastructure being constructed for other proposed development areas - Will be providing detailed submission to expand on comments by March 25, 2011 - Appreciate invitation to attend technical meeting on March 31, 2011	March 10, 2011	- Sent specific response letter and Notice of Completion, October 13/14, 2011
York Gruehl		York Trafalgar Corporation	1039 Fourth Line	Milton, ON	L9T 6P9	Letter	- Writing on behalf of a host of developers with lands in Milton - Would like Master Plan strategy to build in flexibility, phasing and security features - Provided specific comments on display panels presented at PIC 2, including clarification of planning information, evaluation criteria etc.	March 11, 2011	- Sent specific response letter and Notice of Completion, October 13/14, 2011
Michael Telawski	Vice-President, Land Development	M.A.M. Group Inc.	8600 Dufferin Street	Vaughan, ON	L4K 5P5	Letter	-Trinison Management Corp. was an active contributor throughout the ROPA 38 process - Have substantial landholdings throughout Halton, in particular, south of Britannia Rd between 5th Line and Thompson Rd (3rd Line) in Milton - MTE Consultants Inc. provided comments on PIC1 on their behalf - attached preliminary comments from their Consulting Engineers, for review and consideration - Recommend that Halton Region review existing infrastructure to maximize its use and refine future wastewater and water infrastructure alignment, sizing and timing of delivery to service ROPA 38 lands	March 11, 2011	- Sent specific response letter and Notice of Completion, October 13/14, 2011
Mark Pavkovic	Manager	Georgetown Commons				Letter by Email	- Writing on behalf of South Georgetown Landowners Group (including of Lakeview Homes, National Homes, Tribute Communities, Townwood Homes, The Vogue Development Group, and others) - SGLG are located in Halton Hills south of 10th Sideroad, north of 5th Side Rd, east of Trafalgar Rd, and west of 9th Line. - Actively participated during the Sustainable Halton process - Agree with proposal to use a lake-based system to support future growth for both water and wastewater - Hope that final design of any infrastructure should take into account oversizing of infrastructure to service needs beyond 2031 - Requested list of schedules that apply to the various projects	March 11, 2011	- Sent specific response letter and Notice of Completion, October 13/14, 2011
Business Owner						Comment Sheet & Questionnaire	- Suggests placing bulk water stations where they will be most useful - Consideration must be given to the timing of station relocations to avoid negative effects (i.e. wait times, delivery delays etc.) - Suggests stations for portable loading and non-portable loading - Milton locations seem to be planned for the future - Suggest the possibility of locating the bulk water station to Santa Maria in 2011 because of proximity to houses and new sports fields	March 11, 2011.	- Sent specific response letter and Notice of Completion, October 13/14, 2011
Frank Varga			41 Clarinda Drive	North York, ON	M2K 2W4	Letter	- Own about 93 acres south of Derry Rd, west of 8th Line - Support the Preliminary Preferred Strategy, particularly the location of the WWPS near Britannia and Trafalgar Rd. - Suggest oversizing the pipe in anticipation of the Trafalgar Corridor, Steeles Corridor and Georgetown to minimize future DC charges - Suggest investing in Trafalgar/Hwy 401 & Hwy 407/Steeles Corridor	March 11, 2011	-Sent specific response letter and Notice of Completion, October 13/14, 2011
Blair Wolk	Director of Development	Orlando Corporation	6205 Airport Road	Mississauga, ON	L4V 1E3	Letter via Email	- Generally support the Region's Master Plan, but have concerns regarding future build-out of the program as it relates to accommodating growth within 2031 - Employment studies have been showing declining densities within the warehouse and distribution industry - believe employment lands along Trafalgar/Derry and HH corridors will be insufficient to accommodate the targets and requests Region to consider servicing beyond the lands currently designated through the conformity exercise (i.e. ROPA 38)	March 11, 2011	- Sent specific response letter and Notice of Completion, October 13/14, 2011
Resident						Letter	- Long time resident of Milton opposed to transfer of groundwater areas to lake-based servicing - Referenced previous Regional study that looked at blending well and lake water - Concerned with high costs of replacing all infrastructure as part of switchover to lake-based water - Suggests that industrial areas of North Milton be switched over instead - Urges Region to consider alternatives that would keep residents in Old Milton on groundwater	March 11, 2011	- Sent specific response letter and Notice of Completion, October 13/14, 2011
Resident						Email	- Was unaware of proposal to move Timberlea residents to lake based water, would have liked a notice by mail to alert residents - Opposed to move Timberlea neighbourhood to lake based system - Consider upgrades to Kelso supply to meet demands of the community it is currently servicing - industrial and institutional facilities should be considered first well before residential consumers - Would like lake based option to be removed from consideration - Keep informed throughout all phases of project	March 11, 2011.	- Added to mailing list, March 16, 2011 - Colin Best (Councillor Milton) replied to email on March 13, 2011 - Sent response letter, March 16, 2011 -Sent specific response letter and Notice of Completion, October 13/14, 2011

First & Last Name	Title	Company	Address	City, Prov	Postal Code	Type	Comment	Date	Status/Response
Resident						Comment Sheet	- No issues with the projected wells to be drilled North of Acton, both east and west - Concerns about drawing large volumes of water from Prospect Spring - Summer temperatures affect pollution level and algae growth - Decreased rainfall will cause diminished water levels, odour, water quality decreases, and fewer natural watering options for wildlife - Strongly oppose Prospect Well option is a 'preferred option'	March 11, 2011.	- Added to mailing list, March 16, 2011 - Sent response letter, March 16, 2011 - Sent specific response letter and Notice of Completion, October 13/14, 2011
Paul Brown	Director, Land Development	MTE Consultants Inc.	3115 Harvester Road, Suite 200	Burlington, ON	L7N 3N8	Letter by Email	- Writing on behalf of Trinison Management, who own lands south of Britannia Rd between 5th Line and Thompson Rd (3rd Line) in Milton - Requested further discussion regarding wastewater servicing preliminary phasing along Britannia corridor to clarify implications - Requested confirmation if design of Britannia Rd WWPS will provide enhanced system security through provision of emergency storage and standby power - Concerned regarding finalization of the Master Plan in advance of the approved ROPA 38, 39 and the BPEs - Appreciated invitation to technical meeting on March 31, 2011	March 15, 2011	- Sent specific response letter and Notice of Completion, October 13/14, 2011
Jennifer Lawrence	Manager, Environmental Planning	Conservation Halton	2596 Britannia Rd West	Burlington, ON	L7P 0G3	Email	- Requested figures from PIC 2 - For the preliminary recommended solution, has Region looked at impacts to the natural environment, including natural hazards? - Are there any additional new crossings being proposed for Bronte, 16 Mile and 14 Mile Creek - Re: Wastewater servicing for Georgetown, what is being considered in the vicinity of Hwy 401 and 16 Mile Creek - Where is new Trafalgar/Britannia Rd WWPS being considered? - What is involved in the optimization of the WPP plants in Oakville? - Requested further detail regarding the proposed groundwater well expansion and impacts associated with nearby wetlands - Concerned with potential impacts to surrounding natural heritage system (NHS) caused by new gravity sewers	March 29, 2011	- Sent specific response letter and Notice of Completion, October 13/14, 2011
Resident						Phone Call	- Discussion with Halton Region regarding lake-based and groundwater servicing options for Milton	April 12, 2011.	- Added to emailing list, April 18, 2011 - Halton Region provided an email response, April 13, 2011., in addition to a phone conversation - Sent specific response letter and Notice of Completion, October 13/14, 2011
Teresa Wagner	A/Heritage Planner	Ministry of Tourism and Culture	401 Bay Street, Suite 1700	Toronto, ON	M7A 0A7	Email	- Would like update on the status of the Master Plan - Would like to receive a copy of the display boards presented at PIC2 to allow MTC to advise on whether any cultural heritage assessments would be recommended as part of this Class EA	April 12, 2011	- Region responded on April 13, 2011 with link to Master Plan website and a summary of the next steps - Sent Notice of Completion, October 13/14, 2011
Bob Thomson	Chair, Ontario Council	Trout Unlimited Canada	P.O. Box 1014, Station Q	Toronto, ON	M5T 2P2	Letter via Email	- Organization works closely within watersheds of Halton Region - Stressed declining water quality of Credit River - believe comments in the Master Plan are very general in terms of environmental and ecological impacts (i.e. current and historic base flows, temperatures, etc.) - concerns with starting point as referencing the current point rather than reflecting historic or healthy conditions - what innovative approaches to water/wastewater treatment is the Region considering? - would like to see a water conservation plan in the Master Plan - impacts of climate change on groundwater supplies? - would like to see reference to provinces' Water Opportunities and Conservation Act and Source Water Protection Strategies - cannot support the Master Plan given the implications to Trout Unlimited Canada's core policies regarding fish populations and water quantity and quality	April 15, 2011	- Sent specific response letter and Notice of Completion, October 13/14, 2011
Heather Levecque	Manager, Consultation Unit	Ministry of Aboriginal Affairs	160 Bloor Street East, 9th Floor	Toronto, ON	M7A 2E6	Letter	- Master Plan projects appear to be located in an area where First Nations may have existing or asserted rights or claims in MAA's claims process or litigation - provided contacts for information about possible claims in the area	April 21, 2011	- Sent specific response letter and Notice of Completion, October 13/14, 2011
Gordon Patterson	Principal	The Sernas Group	141 Brunel Road	Mississauga, ON	L4Z 1X3	Letter by Email	- Writing on behalf of the South West Georgetown Landowners Group, who own about 405 hectares of land - Suggest interim servicing for Georgetown and Halton Hills 401 Employment lands - Support the Preferred Water Servicing Strategy for Georgetown particularly providing lake-based water from the proposed Zone 4 Reservoir - Support general intention of the Preferred Wastewater Servicing Strategy for Georgetown, particularly extending lake-based servicing - Have concerns with trunk sewer along Ninth Line and the excessive depths that would be required; suggest trunk sewer down Eighth Line from 10th Sideroad to Steeles Ave. - Have concerns with trunk sewer from Hwy 401 down Trafalgar Rd through Milton East expansion area; request that an interim scheme be identified to prevent Georgetown from being left with little or no development; included interim servicing scheme.	April 27, 2011	- Sent specific response letter and Notice of Completion, October 13/14, 2011
Resident						Email	-Resides in Timberlea neighborhood, and supports the switch to the lake based system	April 29, 2011.	- Added to mailing list, April 29, 2011 - Sent Notice of Completion, October 13/14, 2011
York Gruehl		York Trafalgar Corporation	1039 Fourth Line	Milton, ON	L9T 6P9	Letter	- Provided comments regarding ROPA 39 - Wish to further discuss timing issues and review the options and BPE structure	May 5, 2011	- Sent specific response letter and Notice of Completion, October 13/14, 2011
Teresa Wagner	Heritage Planner	Ministry of Tourism and Culture	401 Bay Street, Suite 1700	Toronto, ON	M7A 0A7	Email	- Provided MTC's Checklist for Determining Archaeological Potential and requested that checklist be completed and sent back in order to determine whether an archaeological assessment by an archaeologist licensed under the Ontario Heritage Act will be recommended for this project	May 6, 2011	- Sent Notice of Completion, October 13/14, 2011
Jennifer Lawrence	Manager, Environmental Planning	Conservation Halton	2596 Britannia Rd West	Burlington, ON	L7P 0G3	Letter	- Responding to meeting with Regional staff on April 18, 2011 to discuss the Sustainable Halton Water and Wastewater Master Plan and the options available for the Milton WWTP. - Provided CH opinions/concerns regarding the decommissioning of the Milton WWTP, including information that should be considered in the assessment study	May 24, 2011	- Prefiling consultation - Sent Notice of Completion, October 13/14, 2011

First & Last Name	Title	Company	Address	City, Prov	Postal Code	Type	Comment	Date	Status/Response
Jennifer Lawrence	Manager, Environmental Planning	Conservation Halton	2596 Britannia Rd West	Burlington, ON	L7P 0G3	Letter	- Provided long list of specific comments addressing content in TAC #2 and Baseline Environmental Studies Report: Natural Features and Hydrology,	June 15, 2011	- Sent Notice of Completion, October 13/14, 2011
Carol Gustafson		Milton Green				Letter via Email	- Suggested specific ICI areas to be transferred from groundwater to lake based servicing in Milton - Included map to reference the specific properties and areas - Supports use of water efficient retrofits, especially with new builds, to help conserve water - Suggests existing lake-based service areas be utilized for intensification to help relieve pressure on groundwater areas	July 6, 2011	- Sent specific response letter and Notice of Completion, October 13/14, 2011
Chief Keith Knott		Curve Lake First Nation	22 Winookeeda Road	Curve Lake, ON	K0L 1R0	Letter	- Acknowledges receipt of correspondence and suggests consultation with Karry Sandy-Mackenzie, Claims Coordinator, for issues regarding First Nations Territory's - Not aware of any issues that would cause concern	July 6, 2011	- Sent Notice of Completion, October 13/14, 2011
Karen Chisholme	Planning Ecologist	Credit Valley Conservation	1255 Old Derry Rd	Mississauga, ON	L5N 6R4	Letter	- Provided specific comments for Zones 1-4 after reviewing the Baseline Environmental Studies Report - CVC generally concurs with CH comments as they relate to CVC's watershed jurisdiction and policies	July 22, 2011	- Sent Notice of Completion, October 13/14, 2011
David Johnston	Planner	Niagara Escarpment Commission	232 Guelph Street	Georgetown, ON	L7G 4B1	Email	- Correspondence regarding Project File Binders with Water and Wastewater Capital Program	August 3 to September 6	- Prefiling consultation - Sent Notice of Completion, October 13/14, 2011
Jennifer Lawrence	Manager, Environmental Planning	Conservation Halton	2596 Britannia Rd West	Burlington, ON	L7P 0G3	Email	- Correspondence regarding Project File Binders with Water and Wastewater Capital Program	August 3 to September 6	- Sent Notice of Completion, October 13/14, 2011
David Scott	Founding Partner	The Municipal Infrastructure Group	8800 Dufferin Street, Suite 200	Vaughan, ON	L4K 0C5	Letter	- On behalf of the Boyne Survey West clients, Fieldgate Developments and Great Gulf Homes - Deviation from the plan presented at the February 2011 PIC 2, which identifies that the Boyne lands west of 1st line and east of the CN corridor will not be conveyed to the existing Tremaine SPS but rather diverted to a new 675mm trunk sewer to be constructed along Britannia Road - This change to the Wastewater Strategy can potentially delay development of their lands east of the CN Corridor - Request clarification on the matter - Concerned that the existing Tremaine SPS does not have sufficient capacity for pumping sanitary flows from the Milton Education Village lands in addition to the tributary Milton Phase 2 lands west of 1st Line, the Milton Phase 3 lands west of 1st Line - Requests confirmation of proposed drainage areas and flows to the Tremaine SPS - Suggest that if capacity does not exist, then options for upgrades should be considered	September 30, 2011	- Sent specific response letter and Notice of Completion, October 13/14, 2011