



**2024**

## Halton Region Drinking Water Quality Report: Bridgeview Distribution Subsystem

## Contents

Halton Region Drinking Water Quality Report: Bridgeview Distribution Subsystem .....	1
Introduction .....	3
System Description .....	3
What Improvements Are We Making?.....	3
Water Quality Testing.....	4
Terms.....	4
Microbiological Testing.....	4
Microbiological standards for treated and distributed water: .....	4
Operational Testing.....	4
Chemical Testing .....	5
Inorganic Parameters.....	5
Organic Parameters .....	5
‘Adverse’ Results Notifications.....	5
Community-Wide Lead Sampling Program Results .....	5
More Information or Questions.....	6

## Introduction

Halton Region is committed to providing safe drinking water to all of our customers. As mandated by the Safe Drinking Water Act, 2002, this annual Water Quality Report includes:

- A description of the water treatment process and chemicals used;
- Any major expenses to install, repair or upgrade equipment in the system; and,
- The results of our water tests and how they compare to provincial regulatory standards.

All provincial regulatory monitoring requirements and actions applicable to Halton Region's operation of this system were met or surpassed in the current reporting year.

## System Description

The Bridgeview Distribution Subsystem is operated under the Halton Region Drinking Water System's Municipal Drinking Water Licence. The Bridgeview Distribution Subsystem is located at the west end of the City of Burlington, but it is not connected to the Halton Region Distribution Subsystem. Water is supplied by the City of Hamilton through an interconnection to Hamilton's distribution system on Plains Road. There are approximately 70 homes and businesses in the Bridgeview system.

The City of Hamilton uses chloramination (a combination of chlorine and ammonia) for secondary disinfection in its drinking water system, and so the water in the Bridgeview Distribution Subsystem has a combined chlorine residual rather than a free chlorine residual. In November 2018, the City of Hamilton implemented a new Corrosion Control Program (CCP), approved by the Ministry of the Environment, Conservation and Parks (MECP) by utilizing low concentrations of orthophosphate. A letter outlining Hamilton's CCP was delivered to all affected Halton Region residents and select members of Council ahead of the implementation date.

## What Improvements Are We Making?

No major capital expenses were incurred in the current reporting year. Halton Region continues to support the production and delivery of high quality, safe drinking water through water sampling and monitoring above the provincial requirements, upgrades to the Supervisory Control and Data Acquisition (SCADA) monitoring system and infrastructure management systems, an update of the Water Master Plan and water efficiency programs. Work also continued on the Drinking Water Quality Management System, a provincial requirement to support the licensing of municipal drinking water systems which came into effect for Halton Region in January 2009.

## Water Quality Testing

A large number of water quality tests are performed every day, in accordance with the *Safe Drinking Water Act, 2002 and regulations*. The following sections provide a summary of the test results.

### Terms

CFU/100 mL	Colony-forming units per 100 millilitres of water
µg/L	micrograms per litre
mg/L	milligrams per litre
Standard	Ontario Drinking Water Quality Standard, O.Reg. 169/03

### Microbiological Testing

	Number of Samples	E.coli Results (min-max)	Total Coliform Results (min-max)	Number of HPC Samples	HPC Results (min-max)
Distribution	104	not detected	not detected	63	0-15

#### Microbiological standards for treated and distributed water:

E.coli	not detected
Total Coliforms	not detected
HPC	Heterotrophic Plate Counts are conducted on some distribution system samples. The HPC test is used as a tool to monitor overall quality, but the results are not indicators of water safety. There is no Drinking Water Quality Standard for HPC.

### Operational Testing

The chlorine residual in the distributed water is measured regularly by Halton Region operators. All of the readings are validated by an operator and are also reviewed by the MECP Inspector. 'Adverse' test results must be reported if the combined chlorine residual in the distribution system is <0.25 mg/L and the free chlorine residual is <0.05 mg/L. In the current reporting year, all of the chlorine test results were within the range required by regulation.

## Chemical Testing

### Inorganic Parameters

Parameter	Sample Date	Result Value	Unit of Measure	Standard	Exceedance of Standard
Nitrite	11/13/23	<0.01	mg/L	1.0	No
Nitrate	11/13/23	0.33	mg/L	10.0	No

### Organic Parameters

Parameter	Sample Date	Result Value	Unit of Measure	Standard	Exceedance of Standard
THMs (latest running annual average)	11/13/23	20.8	µg/L	100 (running annual average)	No
HAA (latest running annual average)	11/13/23	5.7	µg/L	80 (running annual average)	No

No additional testing was required by a Municipal Drinking Water License, order or other legal instrument.

### ‘Adverse’ Results Notifications

Notices of ‘adverse’ water quality results are submitted in accordance with the Safe Drinking Water Act, 2002 to the MECP and the Medical Officer of Health. In the current reporting year, there were no adverse water reports for the Bridgeview Distribution Subsystem.

### Community-Wide Lead Sampling Program Results

Under the Community-Wide Lead Sampling Program, samples were collected from two sampling points located within the Bridgeview Distribution Subsystem in the current reporting year. None of the samples contained concentrations of lead above the standard of 10 µg/L.

## More Information or Questions

The related annual Drinking Water Systems Flow Report is presented to Municipal Council members on or before March 31 of each year and is posted on [halton.ca](http://halton.ca)

For alternative formats or questions relating to these documents, email [accesshalton@halton.ca](mailto:accesshalton@halton.ca) or call 311.

Halton Region

Dial 311 or 905-825-6000

Toll free: 1-866-4HALTON (1-866-442-5866)

TTY: 905-827-9833

[www.halton.ca](http://www.halton.ca)