



NOTES:

- THESE DRAWINGS ARE TEMPLATE DRAWINGS
1. REMOVE THIS NOTE AS PART OF THE DESIGN PROCESS.
  2. MODIFY THIS DRAWING AS DIRECTED IN THE SCADA STANDARDS.
  3. ADD ADDITIONAL DETAILS AS REQUIRED TO MEET THE PROJECT SPECIAL REQUIREMENTS.
  4. WHEN THE CONSULTANT DEVIATES FROM THIS TEMPLATE THEY ARE REQUIRED TO NOTIFY HALTON REGION THROUGH THE USE OF THE STANDARD'S DEVIATION METHOD.
  5. FUSED TERMINAL BLOCKS AND CIRCUIT BREAKERS TO BE SIZED APPROPRIATELY.
  6. SHOW ADDITIONAL 100 RIGGS (UP TO A MAXIMUM OF 2) ONLY IF NECESSARY BASED ON DESIGN REQUIREMENTS.
  7. THE CONSULTANT IS TO SPECIFY SIGNAL ISOLATORS WHERE REQUIRED. FOLLOW MANUFACTURER'S SPECIFICATIONS FOR GROUNDING OF SHIELDS.

NO	Date	By	REVISIONS	MANU CAD
Design	---	Ch'kd	---	Date
Drawn	---	Ch'kd	---	
Scale	N.T.S.			References

Field Notes

Stamp

Regional

ACCEPTED FOR CONSTRUCTION OF REGIONAL INFRASTRUCTURE

REVIEWED FOR COMPLIANCE WITH REGIONAL STANDARDS ONLY.

Director, Water & Wastewater Treatment

Manager, Plant Capital & Engineering



TITLE REGIONAL MUNICIPALITY OF HALTON CONSULTANT PROJECT TITLE	
TYPE I & II OUTDOOR SINGLE LINE DIAGRAM	
Consultant File NO	Regional Drawing NO
CONTRACT NO	Drawing NO E811
	SHEET XX OF XX