


STILLING WELL DETAIL – TOP VIEW

1

NTS

EXXX




STILLING WELL DETAIL – SIDE VIEW

2

NTS

EXXX



PRESSURE PROBE HANGING DETAIL

3

NTS

EXXX

CONSULTANT TO UPDATE  
ALL SHEET NO., INCLUDING  
THAT IN TITLEBLOCK

CONSULTANT TO UPDATE  
PROJECT TITLE AND  
DRAWING NAME

**NOTES:**

1. PROBE DOES NOT NEED TO BE ETCHED OR MARKED WITH A SITE CODE

THESE DRAWINGS ARE TEMPLATE DRAWINGS

1. REMOVE THIS NOTE AS PART OF THE DESIGN PROCESS.

2. MODIFY THIS DRAWING AS DIRECTED IN THE SCADA STANDARDS.

3. ADD ADDITIONAL DETAILS AS REQUIRED TO MEET THE PROJECT SPECIAL REQUIREMENTS.

4. WHEN THE CONSULTANT DEVIATES FROM THIS TEMPLATE THEY ARE REQUIRED TO NOTIFY HALTON REGION THROUGH THE USE OF THE STANDARDS DEVIATION MEMO.

5. FUSED TERMINAL BLOCKS AND CIRCUIT BREAKERS TO BE SIZED APPROPRIATELY.

6. SHOW ADDITIONAL RIG RACKS (UP TO A MAXIMUM OF 2) ONLY IF NECESSARY BASED ON DESIGN REQUIREMENTS.

7. THE CONSULTANT IS TO SPECIFY SIGNAL ISOLATORS WHERE REQUIRED. FOLLOW MANUFACTURERS' SPECIFICATIONS FOR GROUNDING OF SHIELDS.

NO	Date	By	REVISIONS	MAN/CAD
Design	---	Ch'kd	---	Date
Drawn	---	Ch'kd	---	
Scale	N.T.S.			References

Field Notes

Stamp

Regional

ACCEPTED FOR CONSTRUCTION OF REGIONAL INFRASTRUCTURE

REVIEWED FOR COMPLIANCE WITH REGIONAL STANDARDS ONLY.

Director, Water & Wastewater Treatment

Manager, Plant Capital & Engineering

**TITLE** REGIONAL MUNICIPALITY OF HALTON  
CONSULTANT PROJECT TITLE

STILLING WELL  
LEVEL PROBE INSTALLATION 2

Consultant File NO	Regional Drawing NO
---	---
CONTRACT NO	Drawing NO
---	E806
	SHEET XX OF XX