



1. FIBRE OPTIC CABLES ARE TO BE LABELED AT BOTH ENDS AND AT EACH TRANSITION. A TRANSITION DEFINED AS A CHANGE IN DUCTING. ALL DUCTING CARRYING FIBRE OPTIC CABLE IS TO BE TAGGED AS 'LAN BACKBONE'.
2. USE FUSION SPLICES FOR SINGLE MODE FIBRE.

THESE DRAWINGS ARE TEMPLATE DRAWINGS

1. REMOVE THIS NOTICE PART OF THE DESIGN PROCESS.
2. MODIFY THIS DRAWING AS DIRECTED IN THE SCADA STANDARDS.
3. ADD ADDITIONAL DETAILS AS REQUIRED TO MEET THE PROJECT SPECIAL REQUIREMENTS.
4. WHEN THE CONSULTANT DEVIATES FROM THIS TEMPLATE THEY ARE REQUIRED TO NOTIFY HALTON REGION THROUGH THE USE OF THE STANDARDS DEVIATION MEMO.
5. FUSED TERMINAL BLOCKS AND CIRCUIT BREAKERS TO BE SIZED APPROPRIATELY.
6. SHOW ADDITIONAL RIO RACKS (UP TO A MAXIMUM OF 2) ONLY IF NECESSARY BASED ON DESIGN REQUIREMENTS.
7. THE CONSULTANT IS TO SPECIFY SIGNAL ISOLATORS WHERE REQUIRED. FOLLOW MANUFACTURERS' SPECIFICATIONS FOR GROUNDING OF SHIELDS.

Field Notes

Stamp

Regional

ACCEPTED FOR CONSTRUCTION
OF REGIONAL INFRASTRUCTURE

REVIEWED FOR COMPLIANCE WITH
REGIONAL STANDARDS ONLY.

Director, Water & Wastewater Treatment

Manager, Plant Capital & Engineering



TITLE REGIONAL MUNICIPALITY OF HALTON
CONSULTANT PROJECT TITLE

SINGLE MODE FIBRE PATCH PANEL PORT ASSIGNMENT

Consultant File NQ

Regional Drawing NΩ

CONTRACT NO

Drawing NO C419

SHEET XX OF XX