



STILLING WELL DETAIL – TOP VIEW
NTS

1
E00X



STILLING WELL DETAIL – SIDE VIEW
NTS

2
E00X



PRESSURE PROBE HANGING DETAIL
NTS

3
E00X

CONSULTANT TO UPDATE
ALL SHEET NO., INCLUDING
THAT IN TITLEBLOCK

CONSULTANT TO UPDATE
PROJECT TITLE AND
DRAWING NAME

NOTES:

- DESIGNER TO DETERMINE IF TYPE 3/4 REQUIRES ONE OR TWO JUNCTION BOXES.
- PROBE DOES NOT NEED TO BE ETCHED OR MARKED WITH A SITE CODE

THESE DRAWINGS ARE TEMPLATE DRAWINGS

- REMOVE THIS NOTE AS PART OF THE DESIGN PROCESS.
- MODIFY THIS DRAWING AS DIRECTED IN THE SCADA STANDARDS.
- ADD ADDITIONAL DETAILS AS REQUIRED TO MEET THE PROJECT SPECIAL REQUIREMENTS.
- WHEN THE CONSULTANT DEVIATES FROM THIS TEMPLATE THEY ARE REQUIRED TO NOTIFY HALTON REGION THROUGH THE USE OF THE STANDARDS DEVIATION MEMO.
- FUSED TERMINAL BLOCKS AND CIRCUIT BREAKERS TO BE SIZED APPROPRIATELY.
- SHOW ADDITIONAL RIG RACKS (UP TO A MAXIMUM OF 2) ONLY IF NECESSARY BASED ON DESIGN REQUIREMENTS.
- THE CONSULTANT IS TO SPECIFY SIGNAL ISOLATORS WHERE REQUIRED. FOLLOW MANUFACTURERS' SPECIFICATIONS FOR GROUNDING OF SHIELDS.

NO	Date	By	REVISIONS	MAN/CAD
Design	---	Ch'kd	---	Date
Drawn	---	Ch'kd	---	
Scale	N.T.S.			References

Field Notes

Stamp

Regional

ACCEPTED FOR CONSTRUCTION OF REGIONAL INFRASTRUCTURE

REVIEWED FOR COMPLIANCE WITH REGIONAL STANDARDS ONLY.

Director, Water & Wastewater Treatment

Manager, Plant Capital & Engineering

TITLE REGIONAL MUNICIPALITY OF HALTON
CONSULTANT PROJECT TITLE

STILLING WELL LEVEL
LEVEL PROBE INSTALLATION 2

Consultant File NO	Regional Drawing NO
---	---
CONTRACT NO	Drawing NO
---	E908
	SHEET XX OF XX