



- NOTES:**
- CABLE AND LIGHTNING ARRESTOR SUPPLIED BY BELL CANADA
 - ROUTER DSL MODEM AND MEDIA CONVERTOR SUPPLIED BY REGION
 - ALL WIRING TO BE DONE TO TIA568B WIRING MAP.
 - BIX BLOCKS TO BE SUPPLIED BY THE CONTRACTOR. FOR OUTDOOR SITES, BIX BLOCKS MAY BE INSIDE THE PANEL ENCLOSURE.
 - REFERENCE DRAWINGS E809 FOR THE LOCATION OF THE BIX BLOCK, LIGHTNING PROTECTION AND GROUND LUG FOR OUTDOOR STATIONS.

THESE DRAWINGS ARE TEMPLATE DRAWINGS

- REMOVE THIS NOTE AS PART OF THE DESIGN PROCESS.
- MODIFY THIS DRAWING AS DIRECTED IN THE SCADA STANDARDS.
- ADD ADDITIONAL DETAILS AS REQUIRED TO MEET THE PROJECT SPECIAL REQUIREMENTS.
- WHEN THE CONSULTANT DEVIATES FROM THIS TEMPLATE THEY ARE REQUIRED TO NOTIFY HALTON REGION THROUGH THE USE OF THE STANDARDS DEVIATION MEMO.
- FUSED TERMINAL BLOCKS AND CIRCUIT BREAKERS TO BE SIZED APPROPRIATELY.
- SHOW ADDITIONAL TPO TRACKS.

Field Notes
Stamp

Regional
ACCEPTED FOR CONSTRUCTION
OF REGIONAL INFRASTRUCTURE
REVIEWED FOR COMPLIANCE WITH
REGIONAL STANDARDS ONLY.

Director, Water & Wastewater Treatment

Manager, Plant Capital & Engineering



TITLE REGIONAL MUNICIPALITY OF HALTON CONSULTANT PROJECT TITLE	
REMOTE SITE NETWORK WITHOUT NDE	
Consultant File NO ---	Regional Drawing NO ---
CONTRACT NO ---	Drawing NO 1401 SHEET XX OF XX