



NOTES:

1. CABLE AND LIGHTNING ARRESTOR SUPPLIED BY BELL CANADA.
2. ROUTER, MEDIA CONVERTOR AND DSL MODEM SUPPLIED BY REGION.
3. ALL WIRING TO BE DONE TO TIA568B WIRING MAP.
4. BIX BLOCKS TO BE SUPPLIED BY THE CONTRACTOR. FOR OUTDOOR SITES, BIX BLOCKS MAY BE INSIDE THE PANEL ENCLOSURE.
5. REFERENCE DRAWINGS E809 FOR THE LOCATION OF THE BIX BLOCK, LIGHTNING PROTECTION AND GROUND LUG FOR OUTDOOR STATIONS.

- THESE DRAWINGS ARE TEMPLATE DRAWINGS
1. REMOVE THIS NOTE AS PART OF THE DESIGN PROCESS.
  2. MODIFY THIS DRAWING AS DIRECTED IN THE SCADA STANDARDS.
  3. ADD ADDITIONAL DETAILS AS REQUIRED TO MEET THE PROJECT SPECIAL REQUIREMENTS.
  4. WHEN THE CONSULTANT DEVIATES FROM THIS TEMPLATE THEY ARE REQUIRED TO NOTIFY HALTON REGION THROUGH THE USE OF THE STANDARDS DEVIATION MEMO.
  5. FUSED TERMINAL BLOCKS AND CIRCUIT BREAKERS TO BE SIZED APPROPRIATELY.
  6. SHOW ADDITIONAL R/O RACKS.

		</							

Field Notes

Stamp

Regional  
ACCEPTED FOR CONSTRUCTION  
OF REGIONAL INFRASTRUCTURE  
REVIEWED FOR COMPLIANCE WITH  
REGIONAL STANDARDS ONLY.  
Director, Water & Wastewater Treatment  
Manager, Plant Capital & Engineering



TITLE REGIONAL MUNICIPALITY OF HALTON  
CONSULTANT PROJECT TITLE

TYPE II, III & IV  
WWPS DSL NETWORK

Consultant File NO	Regional Drawing NO
---	---
CONTRACT NO	Drawing NO 1812
---	SHEET XX OF XX