



- THESE DRAWINGS ARE TEMPLATE DRAWINGS**
1. REMOVE THIS NOTE AS PART OF THE DESIGN PROCESS.
 2. ADAPT THIS DRAWING AS DIRECTED IN THE SCADA STANDARDS.
 3. ADD ADDITIONAL DETAIL AS REQUIRED TO MEET THE PROJECT SPECIAL REQUIREMENTS.
 4. WHEN THE CONSULTANT DEVIATES FROM THIS TEMPLATE THEY ARE REQUIRED TO NOTIFY CALSONIC DESIGN GROUP OF THE STANDARD DEVIATION. WHEN FUSED TERMINAL BLOCKS AND CIRCUIT BREAKERS TO BE SIZED APPROPRIATELY. SHOW ADDITIONAL RIG BACKS (UP TO A MAXIMUM OF 2) ONLY IF NECESSARY BASED ON SPECIAL REQUIREMENTS.
 5. THE CONSULTANT IS TO SPECIFY SIGNAL ISOLATORS WHEN REQUIRED. FOLLOW MANUFACTURER'S SPECIFICATIONS FOR GROUNDING OF SHIELDS.

Field Notes
Stamp



Halton
REGION

TITLE REGIONAL MUNICIPALITY OF HALTON CONSULTANT PROJECT TITLE	
TYPE III & IV CONTROL PANEL POWER DISTRIBUTION (1 OF 2)	
Consultant File NO ---	Regional Drawing NO ---
CONTRACT NO ---	Drawing NO 1902 SHEET 1 OF 2

