



NOTES:

THESE DRAWINGS ARE TEMPLATE DRAWINGS

- REMOVE THIS NOTE AS PART OF THE DESIGN PROCESS.
- MODIFY THIS DRAWING AS DIRECTED IN THE SCADA STANDARDS.
- ADD ADDITIONAL DETAILS AS REQUIRED TO MEET THE PROJECT SPECIAL REQUIREMENTS.
- WHEN THE CONSULTANT DEVIATES FROM THIS TEMPLATE THEY ARE REQUIRED TO NOTIFY HALTON REGION THROUGH THE USE OF THE STANDARDS DEVIATION MEMO.
- FUSED TERMINAL BLOCKS AND CIRCUIT BREAKERS TO BE SIZED APPROPRIATELY.
- SHOW ADDITIONAL I/O RACKS (UP TO A MAXIMUM OF 2) ONLY IF NECESSARY BASED ON DESIGN REQUIREMENTS.
- THE CONSULTANT IS TO SPECIFY SIGNAL ISOLATORS WHERE REQUIRED. FOLLOW MANUFACTURERS' SPECIFICATIONS FOR GROUNDING OF SHIELDS.

| NO     | Date   | By    | REVISIONS | MAN/CAD    |
|--------|--------|-------|-----------|------------|
| Design | ---    | Ch'kd | ---       | Date       |
| Drawn  | ---    | Ch'kd | ---       | References |
| Scale  | N.T.S. |       |           |            |

Field Notes

Stamp

Regional

ACCEPTED FOR CONSTRUCTION OF REGIONAL INFRASTRUCTURE

REVIEWED FOR COMPLIANCE WITH REGIONAL STANDARDS ONLY.

Director, Water & Wastewater Treatment

Manager, Plant Capital & Engineering

TITLE REGIONAL MUNICIPALITY OF HALTON CONSULTANT PROJECT TITLE

PUMP STATION P&ID PUMPS 1&2

|                    |                     |
|--------------------|---------------------|
| Consultant File NR | Regional Drawing NR |
| CONTRACT NR        | Drawing NR          |
| SHEET XX OF XX     |                     |