



2025

Halton Region Drinking Water Quality Report:
Acton Drinking Water Subsystem

Contents

Halton Region Drinking Water Quality Report: Acton Drinking Water Subsystem	1
Introduction	3
System Description	3
What Improvements Are We Making?.....	3
Partnership for Safe Water Program.....	4
Water Quality Testing.....	4
Terms.....	4
Microbiological Testing.....	4
Microbiological standards for treated and distributed water	5
Operational Testing.....	5
Chemical Testing	5
Inorganic Parameters.....	5
Organic Parameters	6
‘Adverse’ Results Notifications.....	8
Community-Wide Lead Sampling Program Results	8
Per - and Polyfluoroalkyl Substances (PFAS).....	8
More Information or Questions.....	8

Introduction

Halton Region is committed to providing safe drinking water to all of our customers. As mandated by the *Safe Drinking Water Act, 2002*, this Annual Drinking Water Quality Report summarizes system performance for the period January 1 to December 31 of the reporting year and includes:

- A description of the drinking water treatment process and chemicals used;
- A summary of any major expenses related to the installation, repair or upgrade of system equipment; and
- The results of drinking water quality testing and how they compare to provincial regulatory standards.
- Any adverse test results or other issues, along with the corrective actions taken.

All provincial regulatory monitoring requirements and operational actions applicable to Halton Region's drinking water system were met or surpassed during the current reporting year.

System Description

Drinking Water System Number: 220001673

The Acton Drinking Water System draws water from three well fields. There are two wells in each of the Davidson well field, the Fourth Line well field and the Prospect Park well field. All of the wells use ultraviolet (UV) light for primary disinfection, additionally chlorine (chlorination) is used for secondary disinfection and control of iron and manganese. Hydrofluosilicic acid (fluoridation) is added to the water from all three sources. Both the Davidson and Fourth Line well fields use preliminary and final cartridge filters which contribute to log removal/inactivation credits for some pathogens.

The Prospect Park facility is equipped with greensand filters for the removal of manganese and iron from the water. Treated water from the three sites is pumped to the Churchill Reservoir and the Acton water distribution system. The Acton Drinking Water System is controlled through a Supervisory Control and Data Acquisition (SCADA) system that is monitored twenty-four hours per day, seven days per week.

What Improvements Are We Making?

Approximately \$10,000 was invested in upgrades at the Prospect Park Water Treatment Plant, including ongoing improvements to the ultraviolet disinfection system, which is currently in its final stages. In addition, approximately \$186,369 was invested in watermain projects within the Acton Drinking Water System.

Halton continues to support the production of quality drinking water through increased sampling for groundwater monitoring, the implementation of the source water protection plan (including

capture zone and groundwater vulnerability assessments), upgrades to the SCADA monitoring and infrastructure management systems and water efficiency programs. Work also continued on the Drinking Water Quality Management System, a provincial requirement to support the licensing of municipal drinking water systems which came into effect for Halton in January 2009.

Partnership for Safe Water Program

Halton Region is an active participant in the American Water Works Association's Partnership for Safe Water, an alliance of leading drinking water organizations committed to improving the quality of drinking water delivered to customers. Through this Partnership's comprehensive programs, Halton Region is provided with the tools and framework needed to continuously improve system performance beyond regulatory requirements.

Water Quality Testing

A comprehensive program of water quality testing is performed daily in accordance with the *Safe Drinking Water Act, 2002* and its associated regulations. The following sections summarize the results of this testing and demonstrate compliance with applicable provincial drinking water quality standards.

Terms

CFU/100 mL	Colony-forming units per 100 millilitres of water
µg/L	micrograms per litre
mg/L	milligrams per litre
Standard	Ontario Drinking Water Quality Standard, O.Reg. 169/03

Microbiological Testing

	Number of Samples	E. coli Results (min-max)	Total Coliform Results (min-max)	Number of HPC Samples	HPC Results (min-max)
Raw	613	0 – 3	0 – 95	N/A	N/A
Treated	308	0 – Absent	0 – Absent	156	0 – 2
Distribution	366	Absent	Absent	291	0 - 16

Microbiological standards for treated and distributed water:

E. coli not detected

Total Coliforms not detected

HPC Heterotrophic Plate Counts are conducted on some distribution system samples. The HPC test is used as a tool to monitor overall quality, but the results are not indicators of water safety. There is no Drinking Water Quality Standard for HPC.

Operational Testing

In the Acton Drinking Water System, continuous analyzers measure and record the results of chlorine residual, turbidity and fluoride residual in treated water. All of the readings are validated by an operator and are also reviewed by the Ministry of the Environment, Conservation and Parks (MECP) Inspector. As well, Halton operators measure the chlorine in the distributed water. 'Adverse' test results must be reported if the free chlorine residual at the end of the treatment process is not sufficient to achieve primary inactivation (disinfection) if a free chlorine residual in the distribution system is <0.05 mg/L or if the fluoride residual is >1.5 mg/L. In the current reporting year, all of the validated readings and test results for these parameters were within the ranges required by regulation.

Chemical Testing**Inorganic Parameters**

Parameter	Sample Date	Result Value	Unit of Measure	Standard	Exceedance of Standard
Antimony	04/14/25	<0.0005	mg/L	0.006	No
Arsenic	04/14/25	<0.0005	mg/L	0.01	No
Barium	04/14/25	0.158	mg/L	1.0	No
Boron	04/14/25	0.018	mg/L	5.0	No
Cadmium	04/14/25	<0.0005	mg/L	0.005	No
Chromium	04/14/25	<0.0005	mg/L	0.05	No
Mercury	04/14/25	<0.00006	mg/L	0.001	No
Selenium	04/14/25	<0.0005	mg/L	0.05	No
Sodium	11/03/25	51.8	mg/L	20	Yes – Reported February 2022

Uranium	04/14/25	<0.0010	mg/L	0.02	No
Fluoride	12/15/25	0.77	mg/L	1.5	No
Nitrite	11/03/25	<0.01	mg/L	1.0	No
Nitrate	11/03/25	1.55	mg/L	10.0	No

Organic Parameters

Parameter	Sample Date	Result Value	Unit of Measure	Standard	Exceedance of Standard
Alachlor	04/14/25	<0.50	µg/L	5	No
Atrazine + N-dealkylated metabolites	04/14/25	<1.0	µg/L	5	No
Azinphos-methyl	04/14/25	<2.0	µg/L	20	No
Benzene	04/14/25	<0.10	µg/L	1	No
Benzo(a)pyrene	04/14/25	<0.0050	µg/L	0.01	No
Bromoxynil	04/14/25	<0.50	µg/L	5	No
Carbaryl	04/14/25	<5.0	µg/L	90	No
Carbofuran	04/14/25	<5.0	µg/L	90	No
Carbon Tetrachloride	04/14/25	0.13	µg/L	2	No
Chlorpyrifos	04/14/25	<1.0	µg/L	90	No
Diazinon	04/14/25	<1.0	µg/L	20	No
Dicamba	04/14/25	<1.0	µg/L	120	No
1,2-Dichlorobenzene	04/14/25	<0.20	µg/L	200	No
1,4-Dichlorobenzene	04/14/25	<0.20	µg/L	5	No
1,2-Dichloroethane	04/14/25	<0.20	µg/L	5	No
1,1-Dichloroethylene (vinylidene chloride)	04/14/25	<0.10	µg/L	14	No
Dichloromethane	04/14/25	<0.50	µg/L	50	No
2-4 Dichlorophenol	04/14/25	<0.25	µg/L	900	No
2,4-Dichlorophenoxy acetic acid (2,4- D)	04/14/25	<1.0	µg/L	100	No
Diclofop-methyl	04/14/25	<0.90	µg/L	9	No
Dimethoate	04/14/25	<2.5	µg/L	20	No
Diquat	04/14/25	<7.0	µg/L	70	No

Diuron	04/14/25	<10	µg/L	150	No
Glyphosate	04/14/25	<10	µg/L	280	No
HAA (latest running annual average)	11/10/25	11.8	µg/L	80 (running annual average)	No
2-Methyl-4-chlorophenoxyacetic acid	04/14/25	<10	µg/L	100	No
Malathion	04/14/25	<5.0	µg/L	190	No
Metolachlor	04/14/25	<0.50	µg/L	50	No
Metribuzin	04/14/25	<5.0	µg/L	80	No
Monochlorobenzene	04/14/25	<0.10	µg/L	80	No
Paraquat	04/14/25	<1.0	µg/L	10	No
Pentachlorophenol	04/14/25	<0.50	µg/L	60	No
Phorate	04/14/25	<0.50	µg/L	2	No
Picloram	04/14/25	<5.0	µg/L	190	No
Polychlorinated Biphenyls (PCB)	04/14/25	<0.05	µg/L	3	No
Prometryne	04/14/25	<0.25	µg/L	1	No
Simazine	04/14/25	<1.0	µg/L	10	No
THM (latest running annual average)	11/10/25	29.3	µg/L	100 (running annual average)	No
Terbufos	04/14/25	<0.50	µg/L	1	No
Tetrachloroethylene	04/14/25	<0.10	µg/L	10	No
2,3,4,6-Tetrachlorophenol	04/14/25	<0.50	µg/L	100	No
Triallate	04/14/25	<1.0	µg/L	230	No
Trichloroethylene	04/14/25	<0.10	µg/L	5	No
2,4,6-Trichlorophenol	04/14/25	<0.50	µg/L	5	No
Trifluralin	04/14/25	<1.0	µg/L	45	No
Vinyl Chloride	04/14/25	<0.20	µg/L	1	No

No additional testing was required by a Municipal Drinking Water License, order, or other legal instruments.

‘Adverse’ Results Notifications

Notices of ‘adverse’ water quality results are submitted to the MECP and the Medical Officer of Health in accordance with the *Safe Drinking Water Act, 2002*. During the current reporting year, no adverse water quality reports were reported for the Acton Drinking Water System.

Community-Wide Lead Sampling Program Results

As part of the Community-Wide Lead Sampling Program, water samples were collected from eight locations throughout the Acton Drinking Water System during the current reporting year. None of the samples exceeded the provincial lead standard of 10 µg/L.

Per - and Polyfluoroalkyl Substances (PFAS)

In August 2024, Health Canada introduced a new drinking water objective of 30 ng/L for the sum concentration of 25 PFAS compounds. In 2025, Halton Region proactively tested raw and treated water at all of its water treatment facilities to assess PFAS levels Region-wide. All results were below the federal objective. Halton Region has also established an annual monitoring program to ensure PFAS levels remain low and to continue protecting the safety of the drinking water supply. The Region keeps current on the changing regulatory environment for this emerging contaminant and will be prepared should adjustments to the monitoring strategy or treatment operations be required.

More Information or Questions

The related Annual Drinking Water Systems Flow Report is presented to Municipal Council members on or before March 31 of each year and is available on [halton.ca](https://www.halton.ca)

For alternative formats or questions relating to these documents, email accesshalton@halton.ca or call 311.

Halton Region
Dial 311 or 905-825-6000
Toll free: 1-866-4HALTON (1-866-442-5866)
TTY: 905-827-9833
www.halton.ca

